

CITY OF WHITE SALMON  
KLICKITAT COUNTY  
WASHINGTON  
CONTRACT DOCUMENTS  
FOR  
2022 GARFIELD STREET AND JEWETT ROUNDABOUT PROJECT



FOR INFORMATION CALL:  
DUSTIN CONROY 509-773-4945

DATE: 5/2/22

# TABLE OF CONTENTS

## BID INFORMATION

ADVERTISEMENT FOR BID . . . . .	1
INFORMATION FOR BIDDERS . . . . .	2 THRU 5

## BID DOCUMENTS

Bidders Check List . . . . .	1
Proposal . . . . .	2
Certificate of Site Inspection . . . . .	3
Bid Schedule . . . . .	4
Non-Collusion Affidavit . . . . .	5
Bid Bond . . . . .	6
Certification of Bidder's Experience and Qualifications . . . . .	7
List of Subcontractors . . . . .	8
Compliance Statement . . . . .	9 THRU 10
Signature Page . . . . .	11
Mandatory Bidder Responsibility Checklist . . . . .	12
Statement of Bidders Qualifications . . . . .	13 THRU 14

## CONTRACT FORMS

Notice of Award . . . . .	1
Contract . . . . .	2 THRU 4
Performance Bond . . . . .	5 THRU 6
Labor and Material Payment Bond . . . . .	7 THRU 8
Certificate of Owners Attorney . . . . .	9
Notice to Proceed . . . . .	10

## WASHINGTON STATE PREVAILING WAGE RATES

## AMENDMENTS TO THE STANDARD SPECIFICATIONS

## SPECIAL PROVISIONS

## DETAILS AND DRAWINGS

Under Separate Cover

## ADVERTISEMENT FOR BIDS

Sealed bids for the construction of **2021 GARFIELD STREET IMPROVEMENTS for the CITY OF WHITE SALMON** will be received by the CITY OF WHITE SALMON, at City Hall, PO Box 2139, **100 N. Main**, White Salmon, WA 98672 until **11:00 AM, Thursday June 2, 2022, LOCAL TIME**, *Bids received after 11:00 AM will not be considered.* Bids will then be collected and transported in a sealed carton to the City Council Chambers at 119 NE Church Street in White Salmon. At approximately 11:15 AM Local Time, or as close thereto as possible, bids will be publicly opened.

The contract documents, and any plans and specifications will be on file after May 11, 2022 at 100 N Main, White Salmon, WA 98672 and will be open to inspection. City contact is Patrick Munyan, Public Works Director, 509-493-1133; fax 509-493-1231.

The City of White Salmon is an equal opportunity and affirmative action employer. Small, minority- and women-owned businesses are encouraged to submit bids. All work performed on the project will be subject to prevailing state wage rates. This project is funded by a grant implemented through the Washington State Transportation Improvement Board (TIB), and The City of White Salmon.

### DESCRIPTION OF WORK:

The project includes the following approximate major work descriptions:

Base Bid: 1200 cyd of excavation, 1038 tons of crushed surfacing, 470 tons of hot mix asphalt, 1,296 syd of pavement grinding, 1580 syd of pavement removal, 1,111 feet of curb and gutter, 265 syd of concrete sidewalk and driveway, 146 feet of 12" storm and 3 catch basins.

### BIDDING DOCUMENTS:

Free-of-charge access to project bid documents (plans, specifications, addenda, and Bidders List) is provided to Prime Bidders, Subcontractors, and Vendors by going to [www.bxwa.com](http://www.bxwa.com) and clicking on "Posted Projects", "Public Works", and "City of White Salmon". This online plan room provides Bidders with fully usable online documents with the ability to: download, view, print, order full/partial plan sets from numerous reprographic sources, and a free online digitizer/take-off tool. It is recommended that Bidders "Register" in order to receive automatic e-mail notification of future addenda and to place themselves on the "Self-Registered Bidders List". Bidders that do not register will not be automatically notified of addenda and will need to periodically check the on-line plan room for addenda issued on this project. Contact Builders Exchange of Washington at (425) 258-1303 should you require assistance with access or registration.

Bids must be submitted on the form of proposal specified in the Contract Documents. The CITY OF WHITE SALMON reserves the right to reject any or all proposals and to waive irregularities or informalities as well as award separate schedules in any manner that may benefit the CITY OF WHITE SALMON.

PRE-BID CONFERENCE: A one-time pre-bid conference and job site review will be held at 1:00 pm May 26, 2022 at City Council Chambers, 119 NE. Church St., White Salmon WA to discuss the project and answer any questions.

BID SECURITY: A certified or bank cashier's check in the amount of five percent (5%) of the bid amount, payable to the City of White Salmon or bid bond executed by a licensed bonding company is required with each bid.

By: \_\_\_\_\_ Marla Keethler, Mayor

Date: \_\_\_\_\_

## INFORMATION TO BIDDERS

BIDS will be received by The City of White Salmon (herein called the "OWNER"),  
at City Hall, White Salmon, WA 98620 until the date and time specified in the  
Invitation to bid and then at said office publicly opened and read aloud.

Each BID must be submitted in a sealed envelope, addressed to City Clerk, City Hall, at P.O. Box 2139, 100 N. Main, White Salmon, WA, 98672. Each sealed envelope containing a BID must be plainly marked on the outside as BID for 2022 Garfield Street Improvement Project and the envelope should bear on the outside the Bidder's name, address, and license number if applicable, and the name of the project for which the BID is submitted. If forwarded by mail, the sealed envelope containing the BID must be enclosed in another envelope addressed to the OWNER at City Hall, White Salmon, WA 98672.

All BIDS must be made on the required BID form. All blank spaces for BID prices must be filled in, in ink or typewritten, and the BID form must be fully completed and executed when submitted. Only one copy of the BID form is required. Receipt of any Addenda shall be noted on the outside, bottom left corner of the sealed envelope.

The OWNER may waive any informalities or minor defects or reject any and all BIDS. Any BID may be withdrawn prior to the above scheduled time for the opening of BIDS or authorized postponement thereof. Any BID received after the time and date specified shall not be considered. No BIDDER may withdraw a BID within 90 days after the actual date of the opening thereof. Should there be reasons why the contract cannot be awarded within the specified period, the time may be extended by mutual agreement between the OWNER and the BIDDER.

BIDDERS must satisfy themselves of the accuracy of the estimated quantities in the BID Schedule by examination of the site and a review of the drawings and specifications including ADDENDA. After BIDS have been submitted, the BIDDER shall not assert that there was a misunderstanding concerning the quantities of WORK or of the nature of the WORK to be done.

The OWNER shall provide to BIDDERS prior to BIDDING, all information which is pertinent to, and delineates and describes, the land owned and rights-of-way acquired or to be acquired.

The CONTRACT DOCUMENTS contain the provisions required for the construction of the PROJECT. Information obtained from an officer, agent, or employee of the OWNER or any other person shall not affect the risks or obligations assumed by the CONTRACTOR or relieve the contractor from fulfilling any of the conditions of the contract.

Each BID must be accompanied by a BID bond payable to the OWNER for five percent of the total amount of the BID. As soon as the BID prices have been compared, the OWNER will return the BONDS of all except the three lowest responsible BIDDERS. When the Agreement is executed the bonds of the two remaining unsuccessful BIDDERS will be returned. The BID BOND of the successful BIDDER will be retained until the payment BOND and performance BOND have been executed and approved, after which it will be returned. A certified cashier's check may be used in lieu of a BID BOND.

A performance BOND and a payment BOND each in the amount of 100 percent of the CONTRACT PRICE, with a corporate surety approved by the OWNER, will be required for the faithful performance of the contract.

Attorneys-in-fact who sign BID BONDS or payment BONDS and performance BONDS must file with each BOND a certified and effective dated copy of their power of attorney.

The party to whom the contract is awarded will be required to execute the Agreement and obtain the performance BOND and payment BOND within twenty (20) calendar days from the date when NOTICE OF AWARD is delivered to the BIDDER. The NOTICE OF AWARD shall be accompanied by the necessary Agreement and BOND forms. In case of failure of the BIDDER to execute the Agreement, the OWNER may consider the BIDDER in default, in which case the BID BOND accompanying the proposal shall become the property of the OWNER.

The OWNER within twenty (20) days of receipt of acceptable performance BOND, payment BOND and Agreement signed by the party to whom the Agreement was awarded shall sign the Agreement and return to such party an executed duplicate of the Agreement. Should the OWNER not execute the Agreement within such period, the BIDDER may by WRITTEN NOTICE withdraw the signed Agreement. Such notice of withdrawal shall be effective upon receipt of the notice by the OWNER.

The NOTICE TO PROCEED shall be issued within ten (10) days of the execution of the Agreement by the OWNER. Should there be reasons why the NOTICE TO PROCEED cannot be issued within such period; the time may be extended by mutual agreement between the OWNER AND CONTRACTOR. All permitting and approval must be completed prior to NOTICE TO PROCEED being issued. This is including but not limited to County and WSDOT permits and approval. If the NOTICE TO PROCEED has not been issued within the ten (10) day period or within the period mutually agreed upon, the CONTRACTOR may terminate the Agreement without further liability on the part of either party. If NOTICE TO PROCEED can not be issued for any reason the OWNER reserves the right to postpone or terminate the project without compensation to the CONTRACTOR.

The OWNER may make such investigations as deemed necessary to determine the ability of the BIDDER to perform the WORK, and the BIDDER shall furnish to the OWNER all such information and data for this purpose as the OWNER may request. The OWNER reserves the right to reject any BID if the evidence submitted by, or investigation of, such BIDDER fails to satisfy the OWNER that such BIDDER is properly qualified to carry out the obligations of the Agreement and to complete the WORK contemplated therein.

A conditional or qualified BID will not be accepted.

Award will be made to the lowest responsive BIDDER according to what the City determines to be most beneficial of the possible alternatives or options.

All applicable laws, ordinances, and the rules and regulations of all authorities having jurisdiction over construction of the PROJECT shall apply to the contract throughout.

Each BIDDER is responsible for inspecting the site and for reading and being thoroughly familiar with the CONTRACT DOCUMENTS. The failure or omission of any BIDDER to do any of the foregoing shall in no way relieve any BIDDER from any obligation in respect to its BID.

Further, the successful BIDDER agrees to abide by the requirements under Executive Order No. 11246, as amended, including specifically the provisions of the equal opportunity clause set forth in the Contract Documents.

The successful BIDDER shall supply the names and addresses of major material SUPPLIERS and SUBCONTRACTORS when required to do so by the owner.

Inspection trips for prospective BIDDERS will leave from the office of The City of White Salmon at the time specified in the advertisement.

The ENGINEER is Pioneer Surveying and Engineering Inc. The ENGINEER'S address is 125 Simcoe Drive, Goldendale, WA 98620.

These contract documents shall be used in conjunction with the 2016 WSDOT/APWA Standard Specifications for Road, Bridge and Municipal Construction and with the WSDOT Standard Plans (M21-01), both of which are hereby made a part of these contract documents.

#### AUTHORIZED REPRESENTATIVE

The City shall act as advisor in all matters relating to the Contract, and:

- A. Shall determine the amount, quality, acceptability and fitness of the work materials and equipment which are to be paid for under the Contract, and approve all pay estimates prior to payment by the City;
- B. Shall decide all questions relative to the true construction, interpretation, meaning and intent of the contract documents;
- C. Shall decide all questions relative to the classification and measurement of quantities and materials, and the fulfillment of this Contract;
- D. Shall have the power to reject or disapprove of work or material which does not conform to the contract documents;
- E. May direct the sequence of work where such direction is for the purpose of avoiding conflict with other work being performed by the City or by others in the same general locality. Nothing herein shall be construed as requiring the purchasing agent to direct the method or manner of performing the work.

The decision of the authorized representative in the matters described above shall be final.

The Authorized City Representative for this bid is:

Jan Brending  
City Administrator  
City of White Salmon  
P.O. Box 2139, 100 N. Main  
White Salmon, WA 98672  
(509) 493-1133

#### DISQUALIFICATION OF BIDDERS

The City may at its discretion determine that a bidder is not responsible and reject their Proposal for any of the following reasons:

- A. More than one Proposal submittal on the same project from a bidder under the same or different name;
- B. Evidence of collusion on prior or present bid process;
- C. Bidder not qualified for the work involved or to the extent of his bid;
- D. Unsatisfactory performance record, judged from the standpoint of conduct of work, workmanship or progress as shown by past or current work for the City;
- E. Uncompleted work, whether for the City or otherwise, which might hinder or prevent the prompt completion of the work bid upon;
- F. Failure to pay or settle bills for labor or materials on any former or current contracts;
- G. Bidder has previously defaulted in the performance of or failed to complete a written public contract, or has been convicted of a crime arising from a previous public contract;
- H. Any other inability, financial or otherwise, to perform the work;
- I. Bidder is not authorized to do business in the State of Washington;
- J. For any other reasons deemed proper by the City.

## REJECTION OF BIDS

The City reserves the right to reject any or all bids and to not make an award. The award of the contract, if made by the City, will be made to the qualified bidder submitting the lowest responsible bid as defined above, if it is to the city's best interest to accept such bid. The right is reserved by the City to waive any informalities or errors in the bid that, in the sole opinion of the City do not materially affect the bid.

## LICENSES AND PERMITS

The successful bidder and all sub-contractors shall acquire and/or possess a current City of White Salmon business License and any other licenses and permits which may be required to fulfill obligations of the Contract arising from this Call for bids.

## GUARANTY

All manufactures warrantees and guarantees are to be made to the city of White Salmon

If, within the warranty period, repairs or changes are required in connection with the work the manufacture or his representatives shall promptly, without expense to the owner:

- A: Place in satisfactory condition all guaranteed work;
- B: Correct all damage to the building, site, equipment or contents which is the result of the use of materials, equipment or workmanship which are inferior, defective, or not in accordance with the terms of the contract; and,
- C: Correct any work, material, equipment, or contents of building, structure or site disturbed in fulfilling the guarantee.

Repairs, replacements or changes made under the warranty requirements shall be warranted for the specified warranty period, or for one year. Beginning on the date of the acceptance of the repairs, replacements or changes.

## **BIDDERS CHECK LIST**

**BIDDERS MUST COMPLETE THE FOLLOWING DOCUMENTS IN THEIR INITIAL BID  
TO BE CONSIDERED RESPONSIVE**

Proposal

Certification of Site Inspection

Bid Schedule

Non-Collusion Declaration

Bid Bond

Certification of Bidder's Experience and Qualifications

List of Subcontractors

Compliance Statement

Notice to Prospective Subcontractors

Signature Page

Mandatory Bidder Responsibility Checklist

Statement of Bidder Qualifications



**PROPOSAL**

NOTE TO BIDDER: Please use **BLACK** ink for completing this Proposal form.

City of White Salmon, WA

Project Title: 2022 Garfield Street Improvement Project

Bidder: \_\_\_\_\_

Address: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

Contractor's Washington State Registration No. \_\_\_\_\_

Contractor's Washington State Industrial Ins. No. \_\_\_\_\_

Washington State Tax ID \_\_\_\_\_

Bidder's person to contact for additional information on this Proposal:

Name: \_\_\_\_\_

Telephone: \_\_\_\_\_

**CERTIFICATION OF SITE INSPECTION**

To the City of  
White Salmon, Washington

1. The undersigned hereby certifies that they have personally examined the location and construction details of work as described on the plans and specifications for 2022 Garfield Street Improvement Project

Further, that they have personally inspected the site, that they have satisfied himself as to the quantities involved, including materials and equipment, and conditions of work involved; including the fact that the description of the quantities of work and materials, as included herein, is brief and is intended only to indicate the general nature of the work and to identify the said quantities with the detailed requirements of the Contract Documents. This Proposal is made according to the provisions and under the terms of the Contract Documents, which Documents are hereby made a part of this Proposal, at the following schedule of rates and prices.

2. Unit prices for all items, all extensions and the total amount of the bid are required to be shown.

3. This project will be constructed for any or all of the Bid Schedules

- 1. Bid Schedule 1                      Base Garfield
- 2. Bid Schedule 2                      Jewett Round About

The City reserves the right to award combined or separate bids deemed most advantageous to the City.

The bidder shall submit a proposal for all bid schedules and alternatives.

4. Bidder acknowledges receipt of the following Addendum:

---

---

---

**CITY OF WHITE SALMON**  
**2022 Garfield Street Improvement Project**  
**BID SCHEDULES 1 and 2**

BASE BID - GARFIELD					
BID SCHEDULE 1 - BASE BID					
Item No.	Description	Units	Quantity	Unit Price	Total Price
1	MOBILIZATION	LS	1	\$ -	\$ -
2	RESET TRAFFIC SIGNS	EA	1	\$ -	\$ -
3	ADJUST COVERS AND GRATES TO GRADE (COMMON PROPOSAL)	EA	2	\$ -	\$ -
4	REMOVAL OF STRUCTURES AND OBSTRUCTIONS	LS	1	\$ -	\$ -
5	UNSUITABLE TRENCH AND FOUNDATION MATERIAL (COMMON PROPOSAL)	CY	150	\$ -	\$ -
6	SHORING OR EXTRA EXCAVATION (CLASS A)	LS	1	\$ -	\$ -
7	EXCAVATION	CY	820	\$ -	\$ -
8	CRUSHED SURFACING, BASE COURSE	TON	334	\$ -	\$ -
9	CRUSHED SURFACING, TOP COURSE	TON	150	\$ -	\$ -
10	COMMERCIAL HOT MIX ASPHALT	TON	270	\$ -	\$ -
11	GEOTEXTILE FABRIC	SY	734	\$ -	\$ -
12	PAVEMENT GRINDING	SY	1296	\$ -	\$ -
13	PAVEMENT REMOVAL	SY	670	\$ -	\$ -
14	CURB RAMP	EA	3	\$ -	\$ -
15	CURB AND GUTTER	LF	576	\$ -	\$ -
16	CONCRETE SIDEWALK	SY	180	\$ -	\$ -
17	CONCRETE DRIVEWAY	SY	45	\$ -	\$ -
18	PAINTED STOP LINE	LF	48	\$ -	\$ -
19	PROJECT TEMPORARY TRAFFIC CONTROL	LS	1	\$ -	\$ -
20	ESC LEAD	DAY	25	\$ -	\$ -
21	SURFACE RESTORATION	LS	1	\$ -	\$ -
22	RELOCATE FENCE	LF	304	\$ -	\$ -
<b>SUBTOTAL SCHEDULE 1</b>					<b>\$ -</b>
Total Schedule 1					\$ -
BASE BID - Jewett Roundabout					
BID SCHEDULE 2 - BASE BID					
Item No.	Description	Units	Quantity	Unit Price	Total Price
1	MOBILIZATION	LS	1	\$ -	\$ -
2	REMOVE TRAFFIC SIGNS	EA	2	\$ -	\$ -
3	ADJUST COVERS AND GRATES TO GRADE (COMMON PROPOSAL)	EA	6	\$ -	\$ -
4	REMOVAL OF STRUCTURES AND OBSTRUCTIONS	LS	1	\$ -	\$ -
5	UNSUITABLE TRENCH AND FOUNDATION MATERIAL (COMMON PROPOSAL)	CY	30	\$ -	\$ -
6	EXCAVATION	CY	380	\$ -	\$ -
7	CRUSHED SURFACING, BASE COURSE	TON	374	\$ -	\$ -
8	CRUSHED SURFACING, TOP COURSE	TON	180	\$ -	\$ -
9	COMMERCIAL HOT MIX ASPHALT	TON	200	\$ -	\$ -
10	GEOTEXTILE FABRIC	SY	0	\$ -	\$ -
11	PAVEMENT REMOVAL	SY	910	\$ -	\$ -
12	CURB RAMP	EA	3	\$ -	\$ -
13	CURB AND GUTTER	LF	339	\$ -	\$ -
14	CONCRETE SIDEWALK	SY	40	\$ -	\$ -
15	PROJECT TEMPORARY TRAFFIC CONTROL	LS	1	\$ -	\$ -
16	ESC LEAD	DAY	20	\$ -	\$ -
17	SURFACE RESTORATION	LS	1	\$ -	\$ -
18	CATCH BASIN - STANDARD GRATE	EA	1	\$ -	\$ -
19	12" DIA HDPE STORM SEWER PIPE	LF	146	\$ -	\$ -
20	INSTALL NEW TRAFFIC SIGNS	EA	12	\$ -	\$ -
21	CURB 2 (WSDOT STANDARD PLAN F-10.18-02)	LF	158	\$ -	\$ -
22	CURB 3 (WSDOT STANDARD PLAN F-10.18-02)	LF	38	\$ -	\$ -
23	DOUBLE YELLOW LANE LINE	LF	128	\$ -	\$ -
24	WHITE WIDE DOT CHANNELIZING LINE	LF	100	\$ -	\$ -
25	CROSSWALK LINE	LF	150	\$ -	\$ -
26	CONCRETE MEDIAN	SY	34	\$ -	\$ -
<b>SUBTOTAL SCHEDULE 1</b>					<b>\$ -</b>

## NON - COLLUSION AFFIDAVIT

**I, by signing the proposal, hereby declare, under penalty of perjury under the laws of the United States that the following statements are true and correct.**

1. That the undersigned person(s), firm, association or corporation has (have) not, either directly or indirectly, entered into any agreement, participated in any collusion, or otherwise taken any action in restraint of free competitive bidding in connection with the project for which this proposal is submitted.
2. **That by signing the signature page of this proposal, I am deemed to have signed and have agreed to the provisions of this declaration.**

### **NOTICE TO ALL BIDDERS**

To report bid rigging activities call:

**1-800-424-9071**

The U.S. Department of Transportation (USDOT) operates the above toll-free “hotline” Monday through Friday, 8:00 a.m. to 5:00 p.m., eastern time. Anyone with knowledge of possible bid rigging, bidder collusion, or other fraudulent activities should use the “hotline” to report such activities.

The “hotline” is part of USDOT’s continuing effort to identify and investigate highway construction contract fraud and abuse and is operated under the direction of the USDOT Inspector General. All information will be treated confidentially and caller anonymity will be respected.

**BID BOND**

KNOW ALL MEN BY THESE PRESENTS, that we, the undersigned,

As Principal, and

as Surety, are hereby held and firmly bound unto The City of White Salmon

as OWNER in the penal sum of \_\_\_\_\_ for the payment of which, well and truly to be made, we hereby jointly and severally bind ourselves, successors and assigns.

Signed, this \_\_\_\_\_ day of \_\_\_\_\_, 2022 \_\_\_\_\_. The Condition of

the above obligation is such that whereas the Principal has submitted to

a certain BID, attached hereto and hereby made a part hereof to enter into a contract in writing, for the

\_\_\_\_\_.

NOW, THEREFORE,

(a) If said BID shall be rejected, or

(b) If said BID shall be accepted and the Principal shall execute and deliver a contract in the Form of Contract attachment hereto (properly completed in accordance with said BID) and shall furnish a BOND for faithful performance of said contract, and for the payment of all persons performing Labor furnishing materials in connection therewith, and shall in all other respects perform the agreement created by the acceptance of said BID, then this obligation shall be void, otherwise the same shall remain in force and effect; it being expressly understood and agreed that the liability of the Surety for any and all claims hereunder shall, in no event, exceed the penal amount of this obligation as herein stated.

The Surety, for value received, hereby stipulates and agrees that the obligations of said Surety and its BOND shall be in no way impaired or affected by any extension of the time within which the OWNER may accept such BID; and said Surety does hereby waive notice of any such extension.

IN WITNESS WHEREOF, the Principal and the Surety have hereunto set their hands and seals, and such of them as are corporations have caused their corporate seals to be hereto affixed and these presents to be signed by their proper officers, the day and year first set forth above.

\_\_\_\_\_  
Principal (L.S.)

\_\_\_\_\_  
Surety

By: \_\_\_\_\_

IMPORTANT - Surety companies executing BONDS must appear on the Treasury Department's most current list (Circular 570 as amended) and be authorized the transact business in the state where the project is located.

**CERTIFICATION OF BIDDER'S  
EXPERIENCE AND QUALIFICATIONS**

The undersigned bidder certifies that they are at the time of bidding, and shall be, throughout the period of the contract, licensed by the State of Washington to do the type of work required under the terms of the contract documents. Bidder further certifies that they are skilled and regularly engaged in the general class and type of work called for in the contract documents.

The bidder represents that they are competent, knowledgeable and have special skills on the nature, extent and inherent conditions of the work to be performed. Bidder further acknowledges that there are certain peculiar and inherent conditions existent in the construction of the particular facilities which may create, during the construction program, unusual or peculiar unsafe conditions hazardous to persons and property. Bidder expressly acknowledges that they are aware of such peculiar risks and that he has the skill and experience to foresee and to adopt protective measures to adequately and safely perform the construction work with respect to such hazards.

The undersigned bidder further certifies that they are not included on the U.S. Comptroller General's consolidated list of persons or firms currently debarred for violations of various Public Contracts incorporating Labor Standards Provisions.

Signed this \_\_\_\_\_ day of \_\_\_\_\_, 2022\_\_

\_\_\_\_\_  
Name of Bidder

\_\_\_\_\_  
Contractor's License No. & State

\_\_\_\_\_  
Signature of Bidder

## LIST OF SUBCONTRACTORS

	Name	Category of Work	Approximate Amount
1	_____	_____	_____
2	_____	_____	_____
3	_____	_____	_____
4	_____	_____	_____
5	_____	_____	_____
6	_____	_____	_____
7	_____	_____	_____
8	_____	_____	_____
9	_____	_____	_____
10	_____	_____	_____

## COMPLIANCE STATEMENT

This statement relates to a proposed contract with \_\_\_\_\_

\_\_\_\_\_  
(Name of borrower or grantee)

I am the undersigned bidder or prospective contractor. I represent that :

1. I \_\_\_\_\_ have, \_\_\_\_\_ have not, participated in a previous contract or subcontract subject to executive order 11246 (regarding equal employment opportunity) or a preceding similar Executive order.
2. If I have participated in such a contract or subcontract, I \_\_\_\_\_ have, \_\_\_\_\_ have not, filed all compliances reports that I have been required to file in connection with the contract or subcontract.

If the proposed contract is for \$50,000 or more and I have 50 or more employees, I also represent that --

3. I \_\_\_\_\_ have, \_\_\_\_\_ have not previously had contracts subject to the written affirmative action program requirements of the Secretary of Labor.
4. If I have participated in such a contract or subcontract, I \_\_\_\_\_ have, \_\_\_\_\_ have not, developed and placed on file at each establishment affirmative action programs as required by the rules and regulations of the Secretary of Labor.

I understand that if I have failed to file any compliance reports that have been required of me, I am not eligible and will not be eligible to have my bid considered or to enter into the proposed contract unless and until I make an arrangement regarding such reports that is satisfactory to the Farmers Home Administration or to the office where the reports are required to be filed.

I also certify that I do not maintain or provide for my employees any segregated facilities at any of my establishments, and that I do not permit my employees to perform their services at any location, under my control, where segregated facilities are maintained. I certify further that I will not maintain or provide for my employees any segregated facilities at any of my establishments, and that I will not permit my employees to perform their services at any location, under my control, where segregated facilities are maintained. I agree that a breach of this certification is a violation of the Equal Opportunity clause in my contract. As used in this certification, the term "segregated facilities" means any waiting rooms, work areas, rest rooms and wash rooms, restaurants and other eating areas, time clocks, locker rooms and other storage or dressing areas, parking lots, drinking fountains, recreation or entertainment areas, transportation, and housing facilities provided for employees which are segregated by explicit directive or are in fact segregated on the basis of race, creed, color, or national origin, because of habit, local custom or otherwise. I further agree that (except where I have obtained identical certifications for proposed subcontractors for specific time periods) I will obtain identical certifications from proposed subcontractors prior to the award of subcontracts exceeding \$10,000 which are not exempt from the provisions of the Equal Opportunity clause; that I will retain such certifications in my files; and that I will forward the following notice to such proposed subcontractors (except where the proposed subcontractors have submitted identical certifications for specific time periods): (See Next Page)



**NOTICE TO PROSPECTIVE SUBCONTRACTORS OF REQUIREMENTS FOR  
CERTIFICATIONS OF NON-SEGREGATED FACILITIES**

A certification of Nonsegregated Facilities, as required by the May 9, 1967, order (32F.R. 7439, May 19, 1967) on Elimination of Segregated Facilities, by the Secretary of Labor, must be submitted prior to the award of a subcontract exceeding \$10,000 which is not exempt from the provisions of the Equal Opportunity clause. The certification may be submitted either for each subcontract or for all subcontracts during a period (i.e., quarterly, semiannually, or annually).

NOTE: The penalty for making false statements in offers is prescribed in 18 U.S.C. 1001.

_____	_____
Signature of Bidder or Prospective Contractor	Date
_____	
_____	
_____	
Address (including Zip Code)	

**PROPOSAL**

SIGNATURE OF AUTHORIZED OFFICIAL (S)

\_\_\_\_\_  
SIGNATURE

\_\_\_\_\_  
TITLE

\_\_\_\_\_  
SIGNATURE

\_\_\_\_\_  
TITLE

FIRM NAME: \_\_\_\_\_

ADDRESS: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

PHONE/FAX \_\_\_\_\_

Sworn to before me this

\_\_\_\_\_ day of \_\_\_\_\_, 2022

Notary Public

Corporate Seal  
(If bid is by Corporation)



## Statement of Bidders Qualifications

Name of Firm: \_\_\_\_\_

Address: \_\_\_\_\_

Phone #: \_\_\_\_\_ Fax #: \_\_\_\_\_

Email: \_\_\_\_\_

Contact Person on this Project: \_\_\_\_\_

How many years the Contractor has been engaged, under the current name shown above, in the construction business? \_\_\_\_\_

List at least three major projects of similar nature which have been completed, by the Prime Contractor, in the last five years; including the gross dollar amount of each project, the Owner of the projects name and telephone number, and the Engineer's name.

	<b>Project Name</b>	<b>Gross Amount</b>	<b>Owner</b>	<b>Phone #</b>	<b>Engineer</b>
1)					
2)					
3)					
4)					
5)					
6)					
7)					

General nature of work performed by the Contractor: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

Bidder agrees that the Owner shall have the right to obtain credit reports.

Yes: \_\_\_\_\_ No: \_\_\_\_\_

List the number of superintendents or responsible employees in a supervisory position that work for you at this time that will be working on this project and how long they have worked for your company?

---

---

---

Have you changed bonding companies in the last 5 years? If so, why? \_\_\_\_\_

---

---

Have you ever been involved in a lawsuit or arbitration proceeding in any way relating to a construction project?

---

List the parties, proceedings, claims asserted by all parties, and the disposition of the case. \_\_\_\_\_

---

---

---

Do you have any outstanding payments due to the Department of Revenue? If so, please explain.

---

---

---

**NOTICE OF AWARD**

TO: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

PROJECT Description: 2022 Garfield STREET IMPROVEMENTS

The OWNER has considered the BID submitted by you for the above described WORK in response to its Advertisement for BIDS dated May 11, 2022 and Information for Bidders.

You are hereby notified that your BID has been accepted for items in the amount of \_\_\_\_\_

You are required by the Information for Bidders to execute the Contract and furnish the required CONTRACTOR's Performance BOND, Payment BOND and certificates of insurance within twenty (20) calendar days from the date of this Notice to you.

If you fail to execute said Contract and to furnish said BONDS within twenty (20) days from the date of this Notice, said OWNER will be entitled to consider all your rights arising out of the OWNER's acceptance of your BID as abandoned and as a forfeiture of your BID BOND. The OWNER will be entitled to such other rights as may be granted by law.

You are required to return an acknowledged copy of this NOTICE OF AWARD to the OWNER.

Dated this \_\_\_\_\_ day of \_\_\_\_\_, 2022\_\_.

\_\_\_\_\_

By: \_\_\_\_\_

Title: MAYOR

**ACCEPTANCE OF NOTICE**

Receipt of the above NOTICE OF AWARD is hereby acknowledged by

\_\_\_\_\_ on this the \_\_\_\_\_ day of \_\_\_\_\_, 2022\_\_.

BY \_\_\_\_\_ TITLE \_\_\_\_\_

## CONTRACT

THIS CONTRACT, made this \_\_\_\_\_ day of \_\_\_\_\_, 2022, by and between  
\_\_\_\_\_ CITY OF WHITE SALMON \_\_\_\_\_, hereinafter called "OWNER" and \_\_\_\_\_

doing business as (an individual,) or (a partnership,) or (a corporation) hereinafter called "CONTRACTOR".

WITNESSETH: That for and in consideration of the payments and agreements herein after mentioned:

1. The CONTRACTOR will commence and complete the construction of the  
\_\_\_\_\_ 2022 GARFIELD STREET IMPROVEMENT PROJECT \_\_\_\_\_

2. The CONTRACTOR will furnish all of the materials, supplies, tools, equipment, labor, and other services necessary for the construction and completion of the PROJECT described herein.

3. The CONTRACTOR will commence the work required by the CONTRACT DOCUMENTS within 10 calendar days after the date of the NOTICE TO PROCEED and will complete the same within 25 working days unless the period for completion is extended otherwise by the CONTRACT DOCUMENTS.

4. The CONTRACTOR agrees to perform all of the work described in the CONTRACT DOCUMENTS and comply with the terms therein for the sum of \$ \_\_\_\_\_ or as shown in the BID SCHEDULES.

5. The term "CONTRACT DOCUMENTS" MEANS and includes the following:

- (A) Advertisement for BIDS
- (B) Information for BIDDERS
- (C) BID
- (D) BID BOND
- (E) Agreement
- (F) WSDOT/APWA Standard Specifications and Plans
- (G) Amendments and Special Provisions
- (H) Payment Bond
- (I) Performance Bond
- (J) NOTICE OF AWARD
- (K) NOTICE TO PROCEED
- (L) CHANGE ORDER
- (M) Drawings prepared by PIONEER SURVEYING AND ENGINEERING INC. AND CITY OF WHITE SALMON
- (N) SPECIFICATIONS prepared or issued by PIONEER SURVEYING AND ENGINEERING INC., AND THE CITY OF WHITE SALMON.

(M) ADDENDA:  
NO. \_\_\_\_\_, DATED \_\_\_\_\_, 2022  
\_\_\_\_\_, \_\_\_\_\_, 2022  
\_\_\_\_\_, \_\_\_\_\_, 2022

6. The OWNER will pay to the CONTRACTOR in the manner and at such times as set forth in the General Conditions such amounts as required by the CONTRACT DOCUMENTS.

7. The Agreement shall be binding upon all parties hereto and their respective heirs, executors, administrators, successors, and assigns.

IN WITNESS WHEREOF, The parties hereto have executed or caused to be executed by their duly authorized official, this Agreement in THREE (3) copies each of which shall be deemed an original on the date first above written.



CONTRACTOR:

\_\_\_\_\_

BY \_\_\_\_\_

NAME \_\_\_\_\_  
(Please Type)

ADDRESS \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

(SEAL)

EMPLOYER IDENTIFICATION

NUMBER \_\_\_\_\_

WASHINGTON STATE

TAX ID NO: \_\_\_\_\_

ATTEST:

\_\_\_\_\_

NAME \_\_\_\_\_  
(Please Type)

OWNER:

CITY OF WHITE SALMON

BY \_\_\_\_\_

NAME \_\_\_\_\_

(Please Type)

TITLE \_\_\_\_\_

(SEAL)

ATTEST:

\_\_\_\_\_

NAME \_\_\_\_\_  
(Please Type)

TITLE \_\_\_\_\_

**PERFORMANCE BOND**

We \_\_\_\_\_, as Principal, and \_\_\_\_\_ as Surety, being a surety company incorporated under the laws of the State of \_\_\_\_\_ and authorized to conduct a surety business in the State of Washington, jointly and severally bind ourselves, our heirs, successors and assigns as set forth herein to \_\_\_\_\_ The City of White Salmon, A Washington Municipal corporation \_\_\_\_\_ (hereinafter called the Owner) for payment of the penal sum of \$ \_\_\_\_\_ (US), lawful money of the United States in connection with the Owner's award to the Contractor for a contract for construction ("Contract") of the following Project:

**2022 GARFIELD STREET IMPROVEMENT PROJECT**

THE CONDITION OF THIS OBLIGATION IS SUCH that if the Contractor shall in all respects faithfully perform all obligations and provisions in the said Contract, this obligation shall become null and void; otherwise, it shall remain in full force and effect, and Surety shall defend and indemnify Owner against any loss or damage due to the failure of the Principal to strictly perform all obligations of the contract.

This bond shall remain in force for a period of at least two years after the Substantial Completion Date of the project, with respect to defective workmanship and materials, and shall otherwise secure all other obligation of the Contractor throughout any other periods of limitation.

This bond is provided pursuant to an in compliance with RCW Chapter 39.08, the terms and requirements of which statute are incorporated herein as though fully set forth.

Surety agrees that no change, extension of time, modification, or addition to the terms of the Contract, or the work to be performed there under, or to the specifications shall in any way affect its obligation on this bond, and it hereby waives notice thereof.

The Contractor and Surety agree that if the Owner is required to engage the services of an attorney in connection with the enforcement of this bond, each shall be jointly and severally liable to pay the Owner reasonable attorneys' fees, costs and expenses incurred, with or without suit, in addition to the penal sum.

Surety certifies that it is an authorized surety bond issuer, properly authorized to transact surety business in Washington. Surety agrees to be bound by the laws of the State of Washington and Subject itself to the jurisdiction of the courts of the State of Washington.

PERFORMANCE BOND-Continued

Executed in 3 original counterparts on \_\_\_\_\_, 2022.

\_\_\_\_\_  
CONTRACTOR

By \_\_\_\_\_

\_\_\_\_\_  
(Title)

(Attach Acknowledgment of authorized representative of Contractor).

Any claims under this bond made in accordance with RCW 39.08 may be addressed to:

\_\_\_\_\_  
(Name and address of Surety)

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_  
(Name and address if Surety's agent for service of process in Washington if different from above)

\_\_\_\_\_

\_\_\_\_\_  
(Telephone No. of Surety's Washington Agent)

(Attach acknowledgment)

\_\_\_\_\_  
Surety

By \_\_\_\_\_  
Its Attorney-in-Fact

**NOTICE:**

Sureties must be authorized to conduct surety business in Washington and have an agent for service of process in Washington. Certified copy of Power of Attorney must be attached.

Surety companies executing Bonds must appear on the Treasury Department's most current list (Circular 570 as amended) and must be authorized to transact business in the State where the Project is located. In addition the Surety must not exceed the bonding limits set forth in the circular.

**LABOR AND MATERIAL PAYMENT BOND**

We \_\_\_\_\_, as Principal, and \_\_\_\_\_ as Surety, being a surety company incorporated under the laws of the State of \_\_\_\_\_ and authorized to conduct a surety business in the State of Washington, jointly and severally bind ourselves, our heirs, successors and assigns as set forth herein to \_\_\_\_\_ The City of White Salmon, A Washington municipal corporation \_\_\_\_\_ (hereinafter called the Owner) for payment of the penal sum of \$\_\_\_\_\_ (US), lawful money of the United States in connection with the Owner's award to the Contractor for a contract for construction ("Contract") of the following Project:

**2022 Garfield STREET IMPROVEMENTS**

THE CONDITION OF THIS OBLIGATION IS SUCH that if the Contractor shall in all respects faithfully perform all obligations and provisions in the said Contract, and pay all laborers, mechanics, subcontractors, material men, taxing authorizes and all persons who supply such person or persons, or subcontractors with material, equipment and supplies for the carrying on of such work, this obligation shall become null and void; otherwise, it shall remain in full force and effect, and Surety shall defend and indemnify Owner against any loss or damage due to the failure of the Principal to strictly perform all obligations of the contract.

This bond shall be in force until completion of the project and acceptance by the Owner, and also for such period thereafter during which the law allows claims to be filed and sued upon.

This bond is provided pursuant to an in compliance with RCW Chapter 39.08, the terms and requirements of which statute are incorporated herein as though fully set forth.

Surety agrees that no change, extension of time, modification, or addition to the terms of the Contract, or the work to be performed there under, or to the specifications shall in any way affect its obligation on this bond, and it hereby waives notice thereof.

The Contractor and Surety agree that if the Owner is required to engage the services of an attorney in connection with the enforcement of this bond, each shall be jointly and severally liable to pay the Owner reasonable attorneys' fees, costs and expenses incurred, with or without suit, in addition to the penal sum.

Surety certifies that it is an authorized surety bond issuer, properly authorized to transact surety business in Washington. Surety agrees to be bound by the laws of the State of Washington and Subject itself to the jurisdiction of the courts of the State of Washington.

LABOR AND MATERIAL PAYMENT BOND-Continued

Executed in 3 original counterparts on \_\_\_\_\_, 2022.

\_\_\_\_\_  
CONTRACTOR

By \_\_\_\_\_

\_\_\_\_\_  
(Title)

(Attach Acknowledgment of authorized representative of Contractor).

Any claims under this bond made in accordance with RCW 39.08 may be addressed to:

\_\_\_\_\_  
(Name and address of Surety)

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_  
(Name and address if Surety's agent for service of  
process in Washington if different from above)

\_\_\_\_\_

\_\_\_\_\_  
(Telephone No. of Surety's Washington Agent)

(Attach acknowledgment)

\_\_\_\_\_  
Surety

By \_\_\_\_\_  
Its Attorney-in-Fact

**NOTICE:**

Sureties must be authorized to conduct surety business in Washington and have an agent for service of process in Washington. Certified copy of Power of Attorney must be attached.

Surety companies executing Bonds must appear on the Treasury Department's most current list (Circular 570 as amended) and must be authorized to transact business in the State where the Project is located. In addition the Surety must not exceed the bonding limits set forth in the circular.

CERTIFICATE OF OWNERS' ATTORNEY. (Optional)

I, the undersigned, \_\_\_\_\_, the duly authorized and acting legal representative of \_\_\_\_\_, do hereby certify as follows:

I have examined the attached contract (s) and performance and payment bond (s) and the manner of execution thereof, and I am of the opinion that each of the aforesaid agreements are adequate and have been duly executed by the proper parties thereto acting through their duly authorized representatives; that said representatives have full power and authority to execute said agreements on behalf of the respective parties named thereon; and that the foregoing agreements constitute valid and legally binding obligations upon the parties executing the same in accordance with terms, conditions, and provisions thereof.

\_\_\_\_\_

Date:

NOTE: Delete phrase "performance and payment bonds" when not applicable.

**NOTICE TO PROCEED**

TO: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

DATE: \_\_\_\_\_

PROJECT: 2022 GARFIELD STREET  
IMPROVEMENT PROJECT

You are hereby notified to commence WORK in accordance with the Agreement dated \_\_\_\_\_, 2022\_\_\_\_, on or before \_\_\_\_\_, 2022\_\_\_\_, and you are to complete the WORK within \_\_\_\_\_ consecutive working days thereafter. The date of completion of all WORK is therefore \_\_\_\_\_, 2022\_\_\_\_.

Liquidated damages shall be per WSDOT Standard Specifications 1-08.9:

LD = (0.15) x contract amount / working days = cost/day

LD = (0.15) x \_\_\_\_\_ / \_\_\_\_\_ = \$ \_\_\_\_\_ / day

\_\_\_\_\_

BY: \_\_\_\_\_

TITLE: \_\_\_\_\_

**ACCEPTANCE OF NOTICE**

Receipt of the above NOTICE TO PROCEED is hereby acknowledged by

this the \_\_\_\_\_, 2022\_\_\_\_

BY: \_\_\_\_\_

TITLE: \_\_\_\_\_

Employer Identification  
Number \_\_\_\_\_

State of Washington  
 Department of Labor & Industries  
 Prevailing Wage Section - Telephone 360-902-5335  
 PO Box 44540, Olympia, WA 98504-4540

Washington State Prevailing Wage

The PREVAILING WAGES listed here include both the hourly wage rate and the hourly rate of fringe benefits. On public works projects, worker's wage and benefit rates must add to not less than this total. A brief description of overtime calculation requirements are provided on the Benefit Code Key.

Journey Level Prevailing Wage Rates for the Effective Date: 4/29/2022

<u>County</u>	<u>Trade</u>	<u>Job Classification</u>	<u>Wage</u>	<u>Holiday</u>	<u>Overtime</u>	<u>Note</u>	<u>*Risk Class</u>
Klickitat	<a href="#">Electrical Fixture Maintenance Workers</a>	Journey Level	\$14.49		<u>1</u>		<a href="#">View</a>
Klickitat	<a href="#">Electricians - Inside</a>	Journey Level	\$81.90	<u>5A</u>	<u>1B</u>		<a href="#">View</a>
Klickitat	<a href="#">Electricians - Inside</a>	Journeyman, Welder	\$87.44	<u>5A</u>	<u>1B</u>		<a href="#">View</a>
Klickitat	<a href="#">Electricians - Motor Shop</a>	Craftsman	\$15.37		<u>1</u>		<a href="#">View</a>
Klickitat	<a href="#">Electricians - Motor Shop</a>	Journey Level	\$14.69		<u>1</u>		<a href="#">View</a>
Klickitat	<a href="#">Electricians - Powerline Construction</a>	Cable Splicer	\$88.89	<u>5A</u>	<u>4D</u>		<a href="#">View</a>
Klickitat	<a href="#">Electricians - Powerline Construction</a>	Certified Line Welder	\$81.65	<u>5A</u>	<u>4D</u>		<a href="#">View</a>
Klickitat	<a href="#">Electricians - Powerline Construction</a>	Groundperson	\$52.91	<u>5A</u>	<u>4D</u>		<a href="#">View</a>
Klickitat	<a href="#">Electricians - Powerline Construction</a>	Heavy Line Equipment Operator	\$81.65	<u>5A</u>	<u>4D</u>		<a href="#">View</a>
Klickitat	<a href="#">Electricians - Powerline Construction</a>	Journey Level Lineperson	\$81.65	<u>5A</u>	<u>4D</u>		<a href="#">View</a>
Klickitat	<a href="#">Electricians - Powerline Construction</a>	Line Equipment Operator	\$70.02	<u>5A</u>	<u>4D</u>		<a href="#">View</a>
Klickitat	<a href="#">Electricians - Powerline Construction</a>	Meter Installer	\$52.91	<u>5A</u>	<u>4D</u>	<u>8W</u>	<a href="#">View</a>
Klickitat	<a href="#">Electricians - Powerline Construction</a>	Pole Sprayer	\$81.65	<u>5A</u>	<u>4D</u>		<a href="#">View</a>
Klickitat	<a href="#">Electricians - Powerline Construction</a>	Powderperson	\$60.75	<u>5A</u>	<u>4D</u>		<a href="#">View</a>
Klickitat	<a href="#">Electronic Technicians</a>	Journey Level	\$66.73	<u>5A</u>	<u>1B</u>		<a href="#">View</a>
Klickitat	<a href="#">Fence Erectors</a>	Fence Erector	\$43.90	<u>6Z</u>	<u>1M</u>		<a href="#">View</a>
Klickitat	<a href="#">Fence Erectors</a>	Fence Laborer	\$43.90	<u>6Z</u>	<u>1M</u>		<a href="#">View</a>
Klickitat	<a href="#">Flaggers</a>	Journey Level	\$46.94	<u>6Z</u>	<u>1M</u>		<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Anchor Machines	\$51.38	<u>6Z</u>	<u>1M</u>		<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Application (including Pot Power Tender For Same), Applying Protective Material By Hand Or Nozzle On Utility Lines Or Storage Tanks On Project	\$50.81	<u>6Z</u>	<u>1M</u>	<u>8S</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Asbestos Removal	\$51.38	<u>6Z</u>	<u>1M</u>		<a href="#">View</a>



Klickitat	<a href="#">Laborers</a>	Asphalt Plant Laborers	\$50.06	<u>6Z</u>	<u>1M</u>	<u>8T</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Asphalt Raker	\$51.86	<u>6Z</u>	<u>1M</u>		<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Asphalt Spreaders	\$50.06	<u>6Z</u>	<u>1M</u>	<u>8T</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Ballast Regulators	\$51.38	<u>6Z</u>	<u>1M</u>		<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Batch Weighman	\$50.06	<u>6Z</u>	<u>1M</u>	<u>8T</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Bit Grinder	\$51.38	<u>6Z</u>	<u>1M</u>		<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Broomers	\$50.06	<u>6Z</u>	<u>1M</u>	<u>8T</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Brush (power Saw)	\$50.81	<u>6Z</u>	<u>1M</u>	<u>8S</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Brush Burners And Cutters	\$50.06	<u>6Z</u>	<u>1M</u>	<u>8T</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Burners	\$50.81	<u>6Z</u>	<u>1M</u>	<u>8S</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Car And Truck Loaders	\$50.06	<u>6Z</u>	<u>1M</u>	<u>8T</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Carpenter Tender	\$50.06	<u>6Z</u>	<u>1M</u>	<u>8T</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Change-house Man Or Dry Shack Man	\$50.06	<u>6Z</u>	<u>1M</u>	<u>8T</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Chipping Guns	\$50.81	<u>6Z</u>	<u>1M</u>	<u>8S</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Choker Setters	\$50.06	<u>6Z</u>	<u>1M</u>	<u>8T</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Choker Splicer	\$50.81	<u>6Z</u>	<u>1M</u>	<u>8S</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Chuck Tender	\$50.81	<u>6Z</u>	<u>1M</u>	<u>8S</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Clary Power Spreader And Similar Types	\$50.81	<u>6Z</u>	<u>1M</u>	<u>8S</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Clean Up Laborers	\$50.06	<u>6Z</u>	<u>1M</u>	<u>8T</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Clean-up Nozzleman-green-cutter (concrete Rock, Etc.)	\$50.81	<u>6Z</u>	<u>1M</u>	<u>8S</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Concrete Crew, Bull Gang	\$50.81	<u>6Z</u>	<u>1M</u>	<u>8S</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Concrete Laborers	\$50.81	<u>6Z</u>	<u>1M</u>	<u>8S</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Concrete Nozzlemen	\$51.86	<u>6Z</u>	<u>1M</u>		<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Concrete Power Buggyman	\$50.81	<u>6Z</u>	<u>1M</u>	<u>8S</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Concrete Saw Operator	\$51.38	<u>6Z</u>	<u>1M</u>		<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Concrete Saw Operator (walls)	\$51.86	<u>6Z</u>	<u>1M</u>		<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Confined Space / Hole Watch	\$46.94	<u>6Z</u>	<u>1M</u>		<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Crusher Feeder	\$50.81	<u>6Z</u>	<u>1M</u>	<u>8S</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Curing, Concrete	\$50.06	<u>6Z</u>	<u>1M</u>	<u>8T</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Demolition And Wrecking Charred Materials	\$50.81	<u>6Z</u>	<u>1M</u>	<u>8S</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Demolition, Wrecking And Moving Laborers	\$50.06	<u>6Z</u>	<u>1M</u>	<u>8T</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Drill Doctor	\$51.38	<u>6Z</u>	<u>1M</u>		<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Drill Operators, Air Tracks, Cat Drills, Wagon Drills, Rubber-mounted Drills And Other Similar Types, Including At Crusher Plants	\$51.86	<u>6Z</u>	<u>1M</u>		<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Dry Pack Machine	\$50.81	<u>6Z</u>	<u>1M</u>	<u>8S</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Dumpers, Road Oiling Crew	\$50.06	<u>6Z</u>	<u>1M</u>	<u>8T</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Dumpmen (for Grading Crew)	\$50.06	<u>6Z</u>	<u>1M</u>	<u>8T</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Elevator Feeders	\$50.06	<u>6Z</u>	<u>1M</u>	<u>8T</u>	<a href="#">View</a>

Klickitat	<a href="#">Laborers</a>	Erosion Control Specialist	\$50.06	<a href="#">6Z</a>	<a href="#">1M</a>	<a href="#">8T</a>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Final Clean-up	\$46.94	<a href="#">6Z</a>	<a href="#">1M</a>		<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Fine Graders	\$50.06	<a href="#">6Z</a>	<a href="#">1M</a>	<a href="#">8T</a>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Fire Watch	\$46.94	<a href="#">6Z</a>	<a href="#">1M</a>		<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Form Strippers (not Swinging Stages)	\$50.06	<a href="#">6Z</a>	<a href="#">1M</a>	<a href="#">8T</a>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	General Laborer	\$50.06	<a href="#">6Z</a>	<a href="#">1M</a>	<a href="#">8T</a>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Grade Checker	\$51.86	<a href="#">6Z</a>	<a href="#">1M</a>		<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Guard Rail, Median Rail, Reference Post Guide Post, Right-of-way Marker	\$50.06	<a href="#">6Z</a>	<a href="#">1M</a>	<a href="#">8T</a>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Gunite Nozzleman	\$51.86	<a href="#">6Z</a>	<a href="#">1M</a>		<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Gunite Nozzleman Tender	\$50.81	<a href="#">6Z</a>	<a href="#">1M</a>	<a href="#">8S</a>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Gunite Or Sand Blasting Pot Tender	\$50.81	<a href="#">6Z</a>	<a href="#">1M</a>	<a href="#">8S</a>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Hand Placed Sand Blasting (wet)	\$50.81	<a href="#">6Z</a>	<a href="#">1M</a>	<a href="#">8S</a>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Handlers Or Mixers Of All Materials Of An Irritating Nature (including Cement & Lime)	\$50.81	<a href="#">6Z</a>	<a href="#">1M</a>	<a href="#">8S</a>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Hazardous Waste Worker	\$51.38	<a href="#">6Z</a>	<a href="#">1M</a>		<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	High Scalers, Strippers And Drillers Covers Work In Swinging Stages, Chairs Or Belts, Under Extreme Conditions Unusual To Blasting, Barring Down, Or S	\$51.86	<a href="#">6Z</a>	<a href="#">1M</a>		<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Jackhammer	\$50.81	<a href="#">6Z</a>	<a href="#">1M</a>	<a href="#">8S</a>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Laser Beam	\$51.86	<a href="#">6Z</a>	<a href="#">1M</a>		<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Laser Beam (pipe Laying) - Applicable When Employee Assigned To Move, Set Up, Align	\$51.86	<a href="#">6Z</a>	<a href="#">1M</a>		<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Laser Beam (tunnel) - Applicable When Employee Assigned To Move, Set Up, Align	\$51.86	<a href="#">6Z</a>	<a href="#">1M</a>		<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Lead Abatement	\$51.38	<a href="#">6Z</a>	<a href="#">1M</a>		<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Leverman Or Aggregate Spreaders (flaherty And Similar Types)	\$50.06	<a href="#">6Z</a>	<a href="#">1M</a>	<a href="#">8T</a>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Loading Spotters	\$50.06	<a href="#">6Z</a>	<a href="#">1M</a>	<a href="#">8T</a>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Loop Installation	\$51.86	<a href="#">6Z</a>	<a href="#">1M</a>		<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Manhole Building	\$51.38	<a href="#">6Z</a>	<a href="#">1M</a>		<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Material Yard Man (including Electrical)	\$50.06	<a href="#">6Z</a>	<a href="#">1M</a>	<a href="#">8T</a>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Miner - Tunnel	\$51.86	<a href="#">6Z</a>	<a href="#">1M</a>		<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Miner - Tunnel	\$51.86	<a href="#">6Z</a>	<a href="#">1M</a>		<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Mold Remediation Or Removal	\$51.38	<a href="#">6Z</a>	<a href="#">1M</a>		<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Multiple Tampers	\$51.38	<a href="#">6Z</a>	<a href="#">1M</a>		<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Nippers And Timbermen	\$51.38	<a href="#">6Z</a>	<a href="#">1M</a>		<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Nuclear Plant Worker - Lead Shield	\$51.38	<a href="#">6Z</a>	<a href="#">1M</a>		<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Paving Breakers	\$50.81	<a href="#">6Z</a>	<a href="#">1M</a>	<a href="#">8S</a>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Pilot Car	\$46.94	<a href="#">6Z</a>	<a href="#">1M</a>		<a href="#">View</a>

Klickitat	<a href="#">Laborers</a>	Pipe Doping & Wrapping	\$50.81	<u>6Z</u>	<u>1M</u>	<u>8S</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Pipe Layer All Types	\$51.86	<u>6Z</u>	<u>1M</u>		<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Pittsburgh Chipper Operator Or Similar Types	\$50.06	<u>6Z</u>	<u>1M</u>	<u>8T</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Post Hold Digger, Air, Gas Or Electric	\$50.81	<u>6Z</u>	<u>1M</u>	<u>8S</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Pot Tender	\$50.81	<u>6Z</u>	<u>1M</u>	<u>8S</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Powderman	\$51.86	<u>6Z</u>	<u>1M</u>		<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Powderman Tender	\$50.06	<u>6Z</u>	<u>1M</u>	<u>8T</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Power Jacks	\$51.38	<u>6Z</u>	<u>1M</u>		<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Power Saw Operators (bucking & Falling)	\$51.38	<u>6Z</u>	<u>1M</u>		<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Pressure Washer	\$50.81	<u>6Z</u>	<u>1M</u>	<u>8S</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Pumpcrete Nozzleman	\$51.86	<u>6Z</u>	<u>1M</u>		<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Railroad Track Laborers	\$50.06	<u>6Z</u>	<u>1M</u>	<u>8T</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Ribbon Setter, Head	\$50.81	<u>6Z</u>	<u>1M</u>	<u>8S</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Ribbon Setters (including Steel Forms)	\$50.06	<u>6Z</u>	<u>1M</u>	<u>8T</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Rip Rap Man (hand Placed)	\$50.06	<u>6Z</u>	<u>1M</u>	<u>8T</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Rip Rap Man (head)	\$50.81	<u>6Z</u>	<u>1M</u>	<u>8S</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Road Pump Tender	\$50.06	<u>6Z</u>	<u>1M</u>	<u>8T</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Sand Blasting (dry)	\$51.38	<u>6Z</u>	<u>1M</u>		<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Scaffold Tender	\$50.06	<u>6Z</u>	<u>1M</u>	<u>8T</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Sewer Labor	\$50.06	<u>6Z</u>	<u>1M</u>	<u>8T</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Sewer Timbermen	\$51.38	<u>6Z</u>	<u>1M</u>		<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Signalman	\$50.06	<u>6Z</u>	<u>1M</u>	<u>8T</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Skipman	\$50.06	<u>6Z</u>	<u>1M</u>	<u>8T</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Slopers	\$50.06	<u>6Z</u>	<u>1M</u>	<u>8T</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Spraymen	\$50.06	<u>6Z</u>	<u>1M</u>	<u>8T</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Stake Chaser	\$50.06	<u>6Z</u>	<u>1M</u>	<u>8T</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Stake-setter	\$50.81	<u>6Z</u>	<u>1M</u>	<u>8S</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Stockpiler	\$50.06	<u>6Z</u>	<u>1M</u>	<u>8T</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Tampers	\$50.81	<u>6Z</u>	<u>1M</u>	<u>8S</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Tie Back Shoring	\$50.06	<u>6Z</u>	<u>1M</u>	<u>8T</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Timber Faller And Bucker (hand Labor)	\$50.06	<u>6Z</u>	<u>1M</u>	<u>8T</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Toolroom Man (at Job Site)	\$50.06	<u>6Z</u>	<u>1M</u>	<u>8T</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Track Liners	\$51.38	<u>6Z</u>	<u>1M</u>		<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Traffic Control Laborer	\$50.06	<u>6Z</u>	<u>1M</u>	<u>8T</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Traffic Control Supervisor	\$51.86	<u>6Z</u>	<u>1M</u>		<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Tugger Operator	\$51.38	<u>6Z</u>	<u>1M</u>		<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Tunnel Bullgang (above Ground)	\$51.86	<u>6Z</u>	<u>1M</u>		<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Tunnel Chuck Tenders	\$51.86	<u>6Z</u>	<u>1M</u>		<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Tunnel Motorman - Dinky Locomotive	\$51.86	<u>6Z</u>	<u>1M</u>		<a href="#">View</a>

Klickitat	<a href="#">Laborers</a>	Tunnel Muckers, Brakemen	\$51.86	<u>6Z</u>	<u>1M</u>		<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Tunnel Powderman	\$51.86	<u>6Z</u>	<u>1M</u>		<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Tunnel Shield Operator	\$51.86	<u>6Z</u>	<u>1M</u>		<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Vibrating Screed	\$51.38	<u>6Z</u>	<u>1M</u>		<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Vibrators (all Types)	\$51.38	<u>6Z</u>	<u>1M</u>		<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Water Blaster	\$51.38	<u>6Z</u>	<u>1M</u>		<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Weight-man-crusher (aggregate When Used)	\$50.06	<u>6Z</u>	<u>1M</u>	<u>8T</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers</a>	Welder	\$51.38	<u>6Z</u>	<u>1M</u>		<a href="#">View</a>
Klickitat	<a href="#">Laborers - Underground Sewer &amp; Water</a>	General Laborer And Topman	\$50.06	<u>6Z</u>	<u>1M</u>	<u>8T</u>	<a href="#">View</a>
Klickitat	<a href="#">Laborers - Underground Sewer &amp; Water</a>	Pipe Layer	\$51.86	<u>6Z</u>	<u>1M</u>		<a href="#">View</a>
Klickitat	<a href="#">Landscape Construction</a>	Landscape Operator	\$60.37	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Landscape Construction</a>	Landscaping or Planting Laborer	\$39.87	<u>6Z</u>	<u>1M</u>		<a href="#">View</a>
Klickitat	<a href="#">Landscape Maintenance</a>	Groundskeeper	\$14.49		<u>1</u>		<a href="#">View</a>
Klickitat	<a href="#">Plumbers &amp; Pipefitters</a>	Journey Level	\$86.69	<u>6Z</u>	<u>1Q</u>		<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Air Filtration Equipment(group 6)	\$57.15	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Asphalt Plant (any Type) (assistant Engineer Required)(group 2)	\$66.10	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Asphalt, Burner & Reconditioner (any Type), (asst To Engineer If Required)(group 5)	\$60.37	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Asphalt, Extrusion Machine Operator(group 5)	\$60.37	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Asphalt, Paver (screed Man Required)(group 4)	\$61.61	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Asphalt, Pugmill (any Type)(group 6)	\$57.15	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Asphalt, Raker(group 6)	\$57.15	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Asphalt, Roller (any Asphalt Mix)(group 5)	\$60.37	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Asphalt, Roto-mill, Pavement Profiler Under 8 Ft Lateral Cut(group 4)	\$61.61	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Asphalt, Roto-mill, Pavement Profiler, 8 Ft Lateral Cut & Over(group 2)	\$66.10	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Asphalt, Roto-mill, Pavement Profiler, Groundman(group 5)	\$60.37	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Asphalt, Screed(group 4)	\$61.61	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Asphalt, Truck Mounted Spreader, With Screed(group 6)	\$57.15	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Auger Oiler(group 6)	\$57.15	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Auto Grader Or "trimmer" (grade Checker Required)(group 2)	\$66.10	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Back Filling Machine (assistant To Engineer Required)(group 4)	\$61.61	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Backhoe, Robotic, Track And Wheel Type Up To And Including 20,000 Lbs. With Any Attachments(group 4)	\$61.61	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>

Klickitat	<a href="#">Power Equipment Operators</a>	Band Wagons (in Conjunction With Whell Excavator)(group 2)	\$66.10	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Bell Man (any Type Of Comunication)(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Blade Any Type(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Blade, Robotic(group 2)	\$66.10	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Boatman(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Boatman, Licensed(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Bobcat, Skid Steer (< 1yd)(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Boom Type Lifting Device, 5 Ton Capacity Or Less(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Boring Machine (asst To Engineer Required) (group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Broom Self-propelled, Construction Job Site(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Bulldozer Operator, 20,000 Lbs Or Less, Or 100 Horse Or Less(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Bulldozer Operator, Over 20,000 Lbs And More Than 100 Horse Up To 70,000 Lbs(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Bulldozer Over 70,000 Lbs Up To And Including 120,000 Lbs(group 3)	\$64.94	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Bulldozer Over 120,000 Lbs And Above(group 2)	\$66.10	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Bulldozer Robotic Equipment(group 2)	\$66.10	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Cable-plow (any Type)(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Cableway 25 Ton & Over(group 2)	\$66.10	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Cableway Up To 25 Ton(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Canal Trimmer (grade Oiler Required)(group 2)	\$66.10	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Cat Drill (john Henry)(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Cement Pump(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Challenger(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Chip Spreading Machine(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Chippers (asst To Engineer If Required)(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Churn Drill & Earth Boring Machine(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Combination Heavy Duty Mechanic-welder, When Required To Do Both(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Compactor Self Propelled Without Blade(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Compactor With Blade Self Propelled(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Compactor, Multi-engine(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Compactor, Robotic(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Compressor (any Power) 1,250 Cu Ft And Over Total Capacity(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Compressor Operator (any Power) Under 1,250	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>

		Cu Ft Total Capacity(group 6)					
Klickitat	<a href="#">Power Equipment Operators</a>	Concrete Batch Plant And/or Wet Mix (3 Units Or More) (group1)	\$68.00	<u>7B</u>	<u>4G</u>	<u>8U</u>	<u>View</u>
Klickitat	<a href="#">Power Equipment Operators</a>	Concrete Batch Plant And/or Wet Mix Operator (1 & 2 Drums)(group 2)	\$66.10	<u>7B</u>	<u>4G</u>	<u>8U</u>	<u>View</u>
Klickitat	<a href="#">Power Equipment Operators</a>	Concrete Batch Plant Quality Control(group 5)	\$60.37	<u>7B</u>	<u>4G</u>	<u>8U</u>	<u>View</u>
Klickitat	<a href="#">Power Equipment Operators</a>	Concrete Breaker (assistant To Engineer Required)(group 4)	\$61.61	<u>7B</u>	<u>4G</u>	<u>8U</u>	<u>View</u>
Klickitat	<a href="#">Power Equipment Operators</a>	Concrete Canal Line, Assistant To Engineer Required(group 2)	\$66.10	<u>7B</u>	<u>4G</u>	<u>8U</u>	<u>View</u>
Klickitat	<a href="#">Power Equipment Operators</a>	Concrete Curing Machine (riding Type)(group 6)	\$57.15	<u>7B</u>	<u>4G</u>	<u>8U</u>	<u>View</u>
Klickitat	<a href="#">Power Equipment Operators</a>	Concrete Diamond Head Profiler(group 2)	\$66.10	<u>7B</u>	<u>4G</u>	<u>8U</u>	<u>View</u>
Klickitat	<a href="#">Power Equipment Operators</a>	Concrete Paving Road Mixer(group 4)	\$61.61	<u>7B</u>	<u>4G</u>	<u>8U</u>	<u>View</u>
Klickitat	<a href="#">Power Equipment Operators</a>	Concrete Planer(group 5)	\$60.37	<u>7B</u>	<u>4G</u>	<u>8U</u>	<u>View</u>
Klickitat	<a href="#">Power Equipment Operators</a>	Concrete Saw(group 6)	\$57.15	<u>7B</u>	<u>4G</u>	<u>8U</u>	<u>View</u>
Klickitat	<a href="#">Power Equipment Operators</a>	Concrete, Automatic Slip Form Paver (asst To Engineer Required)(group 2)	\$66.10	<u>7B</u>	<u>4G</u>	<u>8U</u>	<u>View</u>
Klickitat	<a href="#">Power Equipment Operators</a>	Concrete, Combination Mixer & Compressor Operator, Guniting Work(group 5)	\$60.37	<u>7B</u>	<u>4G</u>	<u>8U</u>	<u>View</u>
Klickitat	<a href="#">Power Equipment Operators</a>	Concrete, Curb Machine Mechanical Berm, Curb And/or Curb And Gutter(group 5)	\$60.37	<u>7B</u>	<u>4G</u>	<u>8U</u>	<u>View</u>
Klickitat	<a href="#">Power Equipment Operators</a>	Concrete, Finishing Machine(group 5)	\$60.37	<u>7B</u>	<u>4G</u>	<u>8U</u>	<u>View</u>
Klickitat	<a href="#">Power Equipment Operators</a>	Concrete, Grout Plant(group 4)	\$61.61	<u>7B</u>	<u>4G</u>	<u>8U</u>	<u>View</u>
Klickitat	<a href="#">Power Equipment Operators</a>	Concrete, Grouting Machine(group 5)	\$60.37	<u>7B</u>	<u>4G</u>	<u>8U</u>	<u>View</u>
Klickitat	<a href="#">Power Equipment Operators</a>	Concrete, Joint Machine(group 5)	\$60.37	<u>7B</u>	<u>4G</u>	<u>8U</u>	<u>View</u>
Klickitat	<a href="#">Power Equipment Operators</a>	Concrete, Mixer Mobile(group 4)	\$61.61	<u>7B</u>	<u>4G</u>	<u>8U</u>	<u>View</u>
Klickitat	<a href="#">Power Equipment Operators</a>	Concrete, Mixer Single Drum Any Capacity(group 5)	\$60.37	<u>7B</u>	<u>4G</u>	<u>8U</u>	<u>View</u>
Klickitat	<a href="#">Power Equipment Operators</a>	Concrete, Paving Machine 8' And Less (asst To Engineer Required)(group 5)	\$60.37	<u>7B</u>	<u>4G</u>	<u>8U</u>	<u>View</u>
Klickitat	<a href="#">Power Equipment Operators</a>	Concrete, Placing Boom(group 5)	\$60.37	<u>7B</u>	<u>4G</u>	<u>8U</u>	<u>View</u>
Klickitat	<a href="#">Power Equipment Operators</a>	Concrete, Pump Truck(group 5)	\$60.37	<u>7B</u>	<u>4G</u>	<u>8U</u>	<u>View</u>
Klickitat	<a href="#">Power Equipment Operators</a>	Concrete, Pump(group 5)	\$60.37	<u>7B</u>	<u>4G</u>	<u>8U</u>	<u>View</u>
Klickitat	<a href="#">Power Equipment Operators</a>	Concrete, Pumpcrete Operator (any Type)(group 5)	\$60.37	<u>7B</u>	<u>4G</u>	<u>8U</u>	<u>View</u>
Klickitat	<a href="#">Power Equipment Operators</a>	Concrete, Reinforced Tank Banding Machine (asst To Engineer Required)(group 4)	\$61.61	<u>7B</u>	<u>4G</u>	<u>8U</u>	<u>View</u>
Klickitat	<a href="#">Power Equipment Operators</a>	Concrete, Slip Form Pumps, Power Driven Hydraulic Lifting Device For Concrete Forms(group 5)	\$60.37	<u>7B</u>	<u>4G</u>	<u>8U</u>	<u>View</u>
Klickitat	<a href="#">Power Equipment Operators</a>	Concrete, Spreader(group 5)	\$60.37	<u>7B</u>	<u>4G</u>	<u>8U</u>	<u>View</u>
Klickitat	<a href="#">Power Equipment Operators</a>	Concrete, Telebelt(group 5)	\$60.37	<u>7B</u>	<u>4G</u>	<u>8U</u>	<u>View</u>



Klickitat	<a href="#">Power Equipment Operators</a>	Concrete, Treated Base Roller Operator, Oiling(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Conveyor Operator Or Assistant(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Conveyored Material Hauler(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Crane, Bridge Locomotive, Gantry And Overhead(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Crane, Carry Deck(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Crane, Chicago Boom & Similar Types(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Crane, Floating (derrick Barge) 30 Ton But Less Than 150 Ton (asst To Engineer Required)(group 2)	\$66.10	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Crane, Floating 150 Ton But Less Than 250 Ton (asst To Engineer Required) (group 1)	\$68.00	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Crane, Floating 250 Ton And Over (asst To Engineer And Deckhand Required)(group 1)	\$70.16	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Crane, Floating Clamshell 3 Cu. Yds. & Over (fireman Or Diesel Electric Engineer Required)(group 2)	\$66.10	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Crane, Floating Clamshell, Dragline Etc. Operator Under 3 Cu. Yds. Or Less Than 30 Ton (diesel-electric Engineer Required)(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Crane, Hydraulic 200 Ton Through 399 Ton (group 1)	\$68.00	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Crane, Hydraulic 50 Ton Through 89 Ton With Luffing Or Tower Attachment(group 2)	\$66.10	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Crane, Hydraulic 50 Ton Through 89 Tons(group 3)	\$64.94	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Crane, Hydraulic 90 Ton Through 199 Ton With Luffing Or Tower Attachment (group 1)	\$68.00	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Crane, Hydraulic 90 Ton Through 199 Ton(group 2)	\$66.10	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Crane, Hydraulic Crane 200 Ton Through 300 Ton With Luffing Or Tower Attachment(group 1)	\$70.16	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Crane, Hydraulic Crane 400 Ton And Over(group 1)	\$72.32	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Crane, Hydraulic Crane Over 300 Ton Through 399 Ton With Luffer Or Tower Attachment(group 1)	\$72.32	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Crane, Hydraulic Under 50 Ton(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Crane, Lattice Boom 200 Ton Through 299 Ton, With Over 200' Boom(group 1)	\$70.16	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Crane, Lattice Boom 300 Ton Through 399 Ton(group 1)	\$70.16	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Crane, Lattice Boom 300 Ton Through 399 Ton,	\$72.32	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>

		With Over 200' Boom(group 1)					
Klickitat	<a href="#">Power Equipment Operators</a>	Crane, Lattice Boom 50 Ton Through 89 Ton With 150' Boom Or Less(group 3)	\$64.94	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Crane, Lattice Boom 50 Ton Through 89 Ton With Over 150' Boom	\$66.10	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Crane, Lattice Boom 90 Ton Through 199 Ton With 150' - 200' Boom(group 2)	\$66.10	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Crane, Lattice Boom Under 50 Ton(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Crane, Lattice Boom, 200 Ton Through 299 Ton With 200' Boom Or Less (group 1)	\$68.00	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Crane, Lattice Boom, 90 Ton Through 199 Ton With Over 200' Boom (group 1)	\$68.00	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Crane, Shovel, Dragline Or Clamshell 3 Cu. Yds. But Less Than 5 Cu. Yds. (asst To Engineer Required)(group 3)	\$64.94	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Crane, Tower Crane With 175' Tower Or Less And With Less Than 200' Jib(group 2)	\$66.10	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Crane, Tower Crane With Over 175' Tower Or Over 200' Jib (group 1)	\$68.00	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Crane, Tugger(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Crane, Whirley 90 Ton And Over (group 1)	\$68.00	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Crane, Whirley Under 90 Ton(group 2)	\$66.10	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Crusher Feederman(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Crusher Oiler(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Crusher Plant(group 2)	\$66.10	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Deckhand(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Derrick Operator Under 100 Ton (two Operators Required When Swing Control Is Remote From Hoist)(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Diesel-electric Engineer (plant Or Floating) (group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Directional Drill Over 20,000 Lbs Pullback(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Drill Assistant(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Drill Cat Operator(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Drill Directional Type Less Than 20,000 Lbs Pullback(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Drill Doctor And/or (bit Grinder)(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Drill Mud Mixer(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Drill Oscillator(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Drill, Directinal Locator(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Driller, Percussion, Diamond, Core, Cable, Rotary	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>



		& Similar Type(group 4)					
Klickitat	<a href="#">Power Equipment Operators</a>	Elevating Grader Operator, Tractor Towed Requiring Operator Or Grader(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Elevating Loader Operator (any Type)(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Elevator To Move Personnel Or Materials(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Excavator Over 80,000 Lbs Through 130,000 Lbs(group 3)	\$64.94	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Excavator Operator, Over 20,000 Lbs Through 80,000 Lbs(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Excavator Operator, Over 130,000 Lbs(group 2)	\$66.10	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Fireman(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Floating, Crane 350 Ton And Over (asst To Engineer And Deckhand Required)(group 1)	\$72.32	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Fork Lift(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Fork Lift, Over 10 Ton Or Robotic(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Generator Operator(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Grade Checker(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Grade Setter / Layout From Plans(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Grade-all(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Guardrail Machines, I.e. Punch, Auger, Etc. (group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Guardrail Punch Oiler(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Hammer Operator (pile Driver)(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Heavy Duty Repairman Assistant(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Heavy Equipment Robotics Operator Or Mechanic(group 2)	\$66.10	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Helicopter Hoist(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Helicopter Radioman (ground)(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Helicopter When Used In Erecting Workcrane(group 1)	\$68.00	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Hoist Operator, Single Drum(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Hoist, 2 Drums Or More(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Hoist, Stiff Leg, Guy Derrick Or Similar Type, 50 Ton And Over(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Hydraulic Backhoe Track Type Up To And Including 20,000 Lbs(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Hydraulic Backhoe Wheel Type (any Make)(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Hydraulic Pipe Press(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Hydro Axe (loader Mounted Or Similar Type) (group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Hydrographic Seeder Machine Straw, Pulp Or	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>

		Seed(group 6)					
Klickitat	<a href="#">Power Equipment Operators</a>	Hydrostatic Pump Operator(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Internal Full Slab Vibrator Operator(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Jack Operator, Elevating Barges, Barge Operator, Self-unloading (asst To Engineer Required)(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Laser Screed(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Lattice Boom Crane 400 Ton And Over(group 1)	\$72.32	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Lime Spreader, Construction Job Site(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Loaders Operator, Front End & Overhead, 25,000 Lbs And Less Than 60,000 Lbs(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Loaders, 120,000 Lbs And Above(group 2)	\$66.10	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Loaders, 60,000 Lbs And Less Than 120,000 Lbs(group 3)	\$64.94	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Loaders, Rubber-tire Type, Less Than 25,000 Lbs(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Log Skidders(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Master Environmental Maintenance Mechanic(group 2)	\$66.10	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Material Handler(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Mechanic, Heavy Duty(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Mixer Box (c.t.b., Dry Batch, Etc.)(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Oiler(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Parts Man (tool Room)(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Pavement Grinder And Or Grooving Machine (riding Type)(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Pile Driver Operator (not Crane Type) (asst To Engineer Required)(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Pipe Bending, Cleaning, Doping And Wrapping Machines(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Pipe, Cast In Place Pipe Laying Machine(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Plant Oiler(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Pump (any Power)(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Pump Operator, More Than 5 Pumps (any Size) (group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Rail, Ballast Compactor, Regulator Or Tamper Machines(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Rail, Ballast Tamper Multi-purpose(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Rail, Brakeman, Switchman, Motorman(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Rail, Car Mover(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Rail, Clip Applicator(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Rail, High Rail Self Loader Truck(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>

Klickitat	<a href="#">Power Equipment Operators</a>	Rail, Lo-railer(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Rail, Locomotive, 40 Ton And Over (asst To Engineer Required)(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Rail, Shuttle Car Operator(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Rail, Speedswing(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Rail, Switchman(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Rail, Tamping Machine, Mechanical, Self-propelled(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Rail, Track Liner(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Remote Controlled Earth Moving Equipment(group 2)	\$66.10	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Rigger(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Roller Grading (not Asphalt)(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Rubber-tired Dozers And Pushers(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Scraper All Types(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Service Oiler (greaser)(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Shovel, Dragline, Clamshell, 5 Yards And Over(group 2)	\$66.10	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Side-boom(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Skip Loader, Drag Box(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Stump Grinder (loader Mounted Or Similar Type) (group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Surface Heater And Planer(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Sweeper Self-propelled, Construction Job Site(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Tar Pot Fireman (power Agitated) Or Not(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Tractor Rubber-tired, 50 Hp Flywheel & Under(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Tractor, Rubber-tired Over 50 Hp Flywheel(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Trenching Machine 3 Ft Depth And Deeper (asst To The Operator If Required)(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Trenching Machine Operator, Maximum Digging Capacity 3 Ft Depth(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Truck Crane Oiler-driver(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Truck, All Terrain Or Track Type(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Truck, Barrel Type(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Truck, Boom(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Truck, Off-road Trucks, Articulated And Non-articulated Trucks(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Truck, Offroad Trucks, Articulated And Non-	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>

		articulated Trucks(group 5)					
Klickitat	<a href="#">Power Equipment Operators</a>	Truck, Vacuum(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Truck, Water(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Tub Grinder(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Tunnel Boring Machine Mechanic(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Tunnel Boring Machine(group 1)	\$68.00	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Tunnel Segment Plant(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Tunnel Separation Plant(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Tunnel Shaef Loader(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Tunnel, Locomotive, Dinkey(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Tunnel, Micro Boring Tunnel Machine(group 1)	\$68.00	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Tunnel, Mucking Machine(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Tunnel, Power Jumbo Setting Slip Forms, Etc. (group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Tunnel, Shield Operator(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Ultra High Pressure Water Jet Cutting Tool System Operator(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Underwater Equipment, Remote Or Otherwise(group 2)	\$66.10	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Vacuum Blasting Machine Operator(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Water Pulls, Water Wagon(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Welder's Assistant(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Welder; Heavy Duty, Certified Or Not(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Welding Machine(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Wheel Excavation Any Size (grade Oiler Required)(group 2)	\$66.10	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators</a>	Wire Mat Or Brooming Machine(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Air Filtration Equipment(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Asphalt Plant (any Type) (assistant Engineer Required)(group 2)	\$66.10	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Asphalt, Burner & Reconditioner (any Type), (asst To Engineer If Required)(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Asphalt, Extrusion Machine Operator(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Asphalt, Paver (screed Man Required)(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Asphalt, Pugmill (any Type)(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Asphalt, Raker(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Asphalt, Roller (any Asphalt Mix)(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>

	<a href="#">&amp; Water</a>						
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Asphalt, Roto-mill, Pavement Profiler Under 8 Ft Lateral Cut(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Asphalt, Roto-mill, Pavement Profiler, 8 Ft Lateral Cut & Over(group 2)	\$66.10	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Asphalt, Roto-mill, Pavement Profiler, Groundman(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Asphalt, Screed(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Asphalt, Truck Mounted Spreader, With Screed(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Auger Oiler(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Auto Grader Or "trimmer" (grade Checker Required)(group 2)	\$66.10	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Back Filling Machine (assistant To Engineer Required)(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Backhoe, Robotic, Track And Wheel Type Up To And Including 20,000 Lbs. With Any Attachments(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Band Wagons (in Conjunction With Whell Excavator)(group 2)	\$66.10	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Bell Man (any Type Of Communication)(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Blade Any Type(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Blade, Robotic(group 2)	\$66.10	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Boatman(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Boatman, Licensed(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Bobcat, Skid Steer (< 1yd)(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Boom Type Lifting Device, 5 Ton Capacity Or Less(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Boring Machine (asst To Engineer Required) (group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Broom Self-propelled, Construction Job Site(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Bulldozer Operator, 20,000 Lbs Or Less, Or 100 Horse Or Less(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Bulldozer Operator, Over 20,000 Lbs And More Than 100 Horse Up To 70,000 Lbs(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>

Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Bulldozer Over 70,000 Lbs Up To And Including 120,000 Lbs(group 3)	\$64.94	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Bulldozer Over 120,000 Lbs And Above(group 2)	\$66.10	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Bulldozer Robotic Equipment(group 2)	\$66.10	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Cable-plow (any Type)(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Cableway 25 Ton & Over(group 2)	\$66.10	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Cableway Up To 25 Ton(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Canal Trimmer (grade Oiler Required)(group 2)	\$66.10	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Cat Drill (john Henry)(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Cement Pump(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Challenger(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Chip Spreading Machine(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Chippers (asst To Engineer If Required)(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Churn Drill & Earth Boring Machine(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Combination Heavy Duty Mechanic-welder, When Required To Do Both(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Compactor Self Propelled Without Blade(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Compactor With Blade Self Propelled(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Compactor, Multi-engine(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Compactor, Robotic(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Compressor (any Power) 1,250 Cu Ft And Over Total Capacity(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Compressor Operator (any Power) Under 1,250 Cu Ft Total Capacity(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Concrete Batch Plant And/or Wet Mix (3 Units Or More) (group1)	\$68.00	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Concrete Batch Plant And/or Wet Mix Operator (1 & 2 Drums)(group 2)	\$66.10	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>



Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Concrete Batch Plant Quality Control(group 5)	\$60.37	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Concrete Breaker (assistant To Engineer Required)(group 4)	\$61.61	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Concrete Canal Line, Assistant To Engineer Required(group 2)	\$66.10	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Concrete Curing Machine (riding Type)(group 6)	\$57.15	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Concrete Diamond Head Profiler(group 2)	\$66.10	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Concrete Paving Road Mixer(group 4)	\$61.61	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Concrete Planer(group 5)	\$60.37	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Concrete Saw(group 6)	\$57.15	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Concrete, Automatic Slip Form Paver (asst To Engineer Required)(group 2)	\$66.10	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Concrete, Combination Mixer & Compressor Operator, Gunit Work(group 5)	\$60.37	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Concrete, Curb Machine Mechanical Berm, Curb And/or Curb And Gutter(group 5)	\$60.37	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Concrete, Finishing Machine(group 5)	\$60.37	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Concrete, Grout Plant(group 4)	\$61.61	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Concrete, Grouting Machine(group 5)	\$60.37	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Concrete, Joint Machine(group 5)	\$60.37	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Concrete, Mixer Mobile(group 4)	\$61.61	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Concrete, Mixer Single Drum Any Capacity(group 5)	\$60.37	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Concrete, Paving Machine 8' And Less (asst To Engineer Required)(group 5)	\$60.37	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Concrete, Placing Boom(group 5)	\$60.37	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Concrete, Pump Truck(group 5)	\$60.37	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Concrete, Pump(group 5)	\$60.37	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Concrete, Pumpcrete Operator (any Type)(group 5)	\$60.37	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>

Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Concrete, Reinforced Tank Banding Machine (asst To Engineer Required)(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Concrete, Slip Form Pumps, Power Driven Hydraulic Lifting Device For Concrete Forms(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Concrete, Spreader(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Concrete, Telebelt(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Concrete, Treated Base Roller Operator, Oiling(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Conveyor Operator Or Assistant(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Conveyored Material Hauler(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Crane, Bridge Locomotive, Gantry And Overhead(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Crane, Carry Deck(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Crane, Chicago Boom & Similar Types(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Crane, Floating (derrick Barge) 30 Ton But Less Than 150 Ton (asst To Engineer Required)(group 2)	\$66.10	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Crane, Floating 150 Ton But Less Than 250 Ton (asst To Engineer Required) (group 1)	\$68.00	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Crane, Floating 250 Ton And Over (asst To Engineer And Deckhand Required)(group 1)	\$70.16	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Crane, Floating Clamshell 3 Cu. Yds. & Over (fireman Or Diesel Electric Engineer Required)(group 2)	\$66.10	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Crane, Floating Clamshell, Dragline Etc. Operator Under 3 Cu. Yds. Or Less Than 30 Ton (diesel-electric Engineer Required)(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Crane, Hydraulic 200 Ton Through 399 Ton (group 1)	\$68.00	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Crane, Hydraulic 50 Ton Through 89 Ton With Luffing Or Tower Attachment(group 2)	\$66.10	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Crane, Hydraulic 50 Ton Through 89 Tons(group 3)	\$64.94	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Crane, Hydraulic 90 Ton Through 199 Ton With Luffing Or Tower Attachment (group 1)	\$68.00	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Crane, Hydraulic 90 Ton Through 199 Ton(group 2)	\$66.10	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Crane, Hydraulic Crane 200 Ton Through 300 Ton	\$70.16	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>



	<a href="#">&amp; Water</a>	With Luffing Or Tower Attachment(group 1)					
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Crane, Hydraulic Crane 400 Ton And Over(group 1)	\$72.32	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Crane, Hydraulic Crane Over 300 Ton Through 399 Ton With Luffer Or Tower Attachment(group 1)	\$72.32	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Crane, Hydraulic Under 50 Ton(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Crane, Lattice Boom 200 Ton Through 299 Ton, With Over 200' Boom(group 1)	\$70.16	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Crane, Lattice Boom 300 Ton Through 399 Ton(group 1)	\$70.16	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Crane, Lattice Boom 300 Ton Through 399 Ton, With Over 200' Boom(group 1)	\$72.32	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Crane, Lattice Boom 50 Ton Through 89 Ton With 150' Boom Or Less(group 3)	\$64.94	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Crane, Lattice Boom 50 Ton Through 89 Ton With Over 150' Boom	\$66.10	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Crane, Lattice Boom 90 Ton Through 199 Ton With 150' - 200' Boom(group 2)	\$66.10	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Crane, Lattice Boom Under 50 Ton(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Crane, Lattice Boom, 200 Ton Through 299 Ton With 200' Boom Or Less (group 1)	\$68.00	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Crane, Lattice Boom, 90 Ton Through 199 Ton With Over 200' Boom (group 1)	\$68.00	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Crane, Shovel, Dragline Or Clamshell 3 Cu. Yds. But Less Than 5 Cu. Yds. (asst To Engineer Required)(group 3)	\$64.94	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Crane, Tower Crane With 175' Tower Or Less And With Less Than 200' Jib(group 2)	\$66.10	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Crane, Tower Crane With Over 175' Tower Or Over 200' Jib (group 1)	\$68.00	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Crane, Tugger(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Crane, Whirley 90 Ton And Over (group 1)	\$68.00	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Crane, Whirley Under 90 Ton(group 2)	\$66.10	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Crusher Feederman(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Crusher Oiler(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Crusher Plant(group 2)	\$66.10	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>

	<a href="#">&amp; Water</a>						
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Deckhand(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Derrick Operator Under 100 Ton (two Operators Required When Swing Control Is Remote From Hoist)(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Diesel-electric Engineer (plant Or Floating) (group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Directional Drill Over 20,000 Lbs Pullback(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Drill Assistant(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Drill Cat Operator(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Drill Directional Type Less Than 20,000 Lbs Pullback(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Drill Doctor And/or (bit Grinder)(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Drill Mud Mixer(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Drill Oscillator(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Drill, Directinal Locator(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Driller, Percussion, Diamond, Core, Cable, Rotary & Similar Type(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Elevating Grader Operator, Tractor Towed Requiring Operator Or Grader(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Elevating Loader Operator (any Type)(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Elevator To Move Personnel Or Materials(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Excavator Over 80,000 Lbs Through 130,000 Lbs(group 3)	\$64.94	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Excavator Operator, Over 20,000 Lbs Through 80,000 Lbs(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Excavator Operator, Over 130,000 Lbs(group 2)	\$66.10	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Fireman(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Floating, Crane 350 Ton And Over (asst To Engineer And Deckhand Required)(group 1)	\$72.32	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Fork Lift(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>

Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Fork Lift, Over 10 Ton Or Robotic(group 5)	\$60.37	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Generator Operator(group 4)	\$61.61	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Grade Checker(group 6)	\$57.15	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Grade Setter / Layout From Plans(group 4)	\$61.61	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Grade-all(group 4)	\$61.61	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Guardrail Machines, I.e. Punch, Auger, Etc. (group 4)	\$61.61	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Guardrail Punch Oiler(group 6)	\$57.15	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Hammer Operator (pile Driver)(group 4)	\$61.61	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Heavy Duty Repairman Assistant(group 6)	\$57.15	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Heavy Equipment Robotics Operator Or Mechanic(group 2)	\$66.10	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Helicopter Hoist(group 5)	\$60.37	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Helicopter Radioman (ground)(group 6)	\$57.15	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Helicopter When Used In Erecting Workcrane(group 1)	\$68.00	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Hoist Operator, Single Drum(group 5)	\$60.37	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Hoist, 2 Drums Or More(group 4)	\$61.61	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Hoist, Stiff Leg, Guy Derrick Or Similar Type, 50 Ton And Over(group 4)	\$61.61	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Hydraulic Backhoe Track Type Up To And Including 20,000 Lbs(group 5)	\$60.37	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Hydraulic Backhoe Wheel Type (any Make)(group 5)	\$60.37	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Hydraulic Pipe Press(group 6)	\$57.15	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Hydro Axe (loader Mounted Or Similar Type) (group 4)	\$61.61	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Hydrographic Seeder Machine Straw, Pulp Or Seed(group 6)	\$57.15	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Hydrostatic Pump Operator(group 6)	\$57.15	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>

Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Internal Full Slab Vibrator Operator(group 5)	\$60.37	<u>7B</u>	<u>4G</u>	<u>8U</u>	<u>View</u>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Jack Operator, Elevating Barges, Barge Operator, Self-unloading (asst To Engineer Required)(group 4)	\$61.61	<u>7B</u>	<u>4G</u>	<u>8U</u>	<u>View</u>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Laser Screed(group 5)	\$60.37	<u>7B</u>	<u>4G</u>	<u>8U</u>	<u>View</u>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Lattice Boom Crane 400 Ton And Over(group 1)	\$72.32	<u>7B</u>	<u>4G</u>	<u>8U</u>	<u>View</u>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Lime Spreader, Construction Job Site(group 5)	\$60.37	<u>7B</u>	<u>4G</u>	<u>8U</u>	<u>View</u>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Loaders Operator, Front End & Overhead, 25,000 Lbs And Less Than 60,000 Lbs(group 4)	\$61.61	<u>7B</u>	<u>4G</u>	<u>8U</u>	<u>View</u>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Loaders, 120,000 Lbs And Above(group 2)	\$66.10	<u>7B</u>	<u>4G</u>	<u>8U</u>	<u>View</u>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Loaders, 60,000 Lbs And Less Than 120,000 Lbs(group 3)	\$64.94	<u>7B</u>	<u>4G</u>	<u>8U</u>	<u>View</u>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Loaders, Rubber-tire Type, Less Than 25,000 Lbs(group 5)	\$60.37	<u>7B</u>	<u>4G</u>	<u>8U</u>	<u>View</u>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Log Skidders(group 4)	\$61.61	<u>7B</u>	<u>4G</u>	<u>8U</u>	<u>View</u>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Master Environmental Maintenance Mechanic(group 2)	\$66.10	<u>7B</u>	<u>4G</u>	<u>8U</u>	<u>View</u>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Material Handler(group 6)	\$57.15	<u>7B</u>	<u>4G</u>	<u>8U</u>	<u>View</u>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Mechanic, Heavy Duty(group 4)	\$61.61	<u>7B</u>	<u>4G</u>	<u>8U</u>	<u>View</u>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Mixer Box (c.t.b., Dry Batch, Etc.)(group 6)	\$57.15	<u>7B</u>	<u>4G</u>	<u>8U</u>	<u>View</u>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Oiler(group 6)	\$57.15	<u>7B</u>	<u>4G</u>	<u>8U</u>	<u>View</u>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Parts Man (tool Room)(group 6)	\$57.15	<u>7B</u>	<u>4G</u>	<u>8U</u>	<u>View</u>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Pavement Grinder And Or Grooving Machine (riding Type)(group 5)	\$60.37	<u>7B</u>	<u>4G</u>	<u>8U</u>	<u>View</u>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Pile Driver Operator (not Crane Type) (asst To Engineer Required)(group 4)	\$61.61	<u>7B</u>	<u>4G</u>	<u>8U</u>	<u>View</u>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Pipe Bending, Cleaning, Doping And Wrapping Machines(group 4)	\$61.61	<u>7B</u>	<u>4G</u>	<u>8U</u>	<u>View</u>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Pipe, Cast In Place Pipe Laying Machine(group 5)	\$60.37	<u>7B</u>	<u>4G</u>	<u>8U</u>	<u>View</u>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Plant Oiler(group 6)	\$57.15	<u>7B</u>	<u>4G</u>	<u>8U</u>	<u>View</u>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Pump (any Power)(group 6)	\$57.15	<u>7B</u>	<u>4G</u>	<u>8U</u>	<u>View</u>

	<a href="#">&amp; Water</a>						
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Pump Operator, More Than 5 Pumps (any Size) (group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Rail, Ballast Compactor, Regulator Or Tamper Machines(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Rail, Ballast Tamper Multi-purpose(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Rail, Brakeman, Switchman, Motorman(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Rail, Car Mover(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Rail, Clip Applicator(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Rail, High Rail Self Loader Truck(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Rail, Lo-railer(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Rail, Locomotive, 40 Ton And Over (asst To Engineer Required)(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Rail, Shuttle Car Operator(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Rail, Speedswing(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Rail, Switchman(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Rail, Tamping Machine, Mechanical, Self-propelled(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Rail, Track Liner(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Remote Controlled Earth Moving Equipment(group 2)	\$66.10	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Rigger(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Roller Grading (not Asphalt)(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Rubber-tired Dozers And Pushers(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Scraper All Types(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Service Oiler (greaser)(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Shovel, Dragline, Clamshell, 5 Yards And Over(group 2)	\$66.10	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer</a>	Side-boom(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>

	<a href="#">&amp; Water</a>						
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Skip Loader, Drag Box(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Stump Grinder (loader Mounted Or Similar Type) (group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Surface Heater And Planer(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Sweeper Self-propelled, Construction Job Site(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Tar Pot Fireman (power Agitated) Or Not(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Tractor Rubber-tired, 50 Hp Flywheel & Under(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Tractor, Rubber-tired Over 50 Hp Flywheel(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Trenching Machine 3 Ft Depth And Deeper (asst To The Operator If Required)(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Trenching Machine Operator, Maximum Digging Capacity 3 Ft Depth(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Truck Crane Oiler-driver(group 6)	\$57.15	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Truck, All Terrain Or Track Type(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Truck, Barrel Type(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Truck, Boom(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Truck, Off-road Trucks, Articulated And Non-articulated Trucks(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Truck, Offroad Trucks, Articulated And Non-articulated Trucks(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Truck, Vacuum(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Truck, Water(group 5)	\$60.37	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Tub Grinder(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Tunnel Boring Machine Mechanic(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Tunnel Boring Machine(group 1)	\$68.00	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Tunnel Segment Plant(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Tunnel Separation Plant(group 4)	\$61.61	<a href="#">7B</a>	<a href="#">4G</a>	<a href="#">8U</a>	<a href="#">View</a>



	<a href="#">&amp; Water</a>						
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Tunnel Shaef Loader(group 4)	\$61.61	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Tunnel, Locomotive, Dinkey(group 5)	\$60.37	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Tunnel, Micro Boring Tunnel Machine(group 1)	\$68.00	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Tunnel, Mucking Machine(group 4)	\$61.61	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Tunnel, Power Jumbo Setting Slip Forms, Etc. (group 5)	\$60.37	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Tunnel, Shield Operator(group 4)	\$61.61	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Ultra High Pressure Water Jet Cutting Tool System Operator(group 4)	\$61.61	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Underwater Equipment, Remote Or Otherwise(group 2)	\$66.10	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Vacuum Blasting Machine Operator(group 4)	\$61.61	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Water Pulls, Water Wagon(group 4)	\$61.61	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Welder's Assistant(group 6)	\$57.15	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Welder; Heavy Duty, Certified Or Not(group 4)	\$61.61	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Welding Machine(group 6)	\$57.15	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Wheel Excavation Any Size (grade Oiler Required)(group 2)	\$66.10	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Equipment Operators- Underground Sewer &amp; Water</a>	Wire Mat Or Brooming Machine(group 6)	\$57.15	<u>7B</u>	<u>4G</u>	<u>8U</u>	<a href="#">View</a>
Klickitat	<a href="#">Power Line Clearance Tree Trimmers</a>	Groundman	\$31.43	<u>7E</u>	<u>4A</u>		<a href="#">View</a>
Klickitat	<a href="#">Power Line Clearance Tree Trimmers</a>	Journey Level in Charge	\$53.52	<u>7E</u>	<u>4A</u>		<a href="#">View</a>
Klickitat	<a href="#">Power Line Clearance Tree Trimmers</a>	Spray Person	\$48.14	<u>7E</u>	<u>4A</u>		<a href="#">View</a>
Klickitat	<a href="#">Power Line Clearance Tree Trimmers</a>	Tree Trimmer	\$48.14	<u>7E</u>	<u>4A</u>		<a href="#">View</a>
Klickitat	<a href="#">Sign Makers &amp; Installers (Electrical)</a>	Journey Level	\$16.83		<u>1</u>		<a href="#">View</a>
Klickitat	<a href="#">Sign Makers &amp; Installers (Non-Electrical)</a>	Journey Level	\$16.83		<u>1</u>		<a href="#">View</a>
Klickitat	<a href="#">Surveyors</a>	Chain Person	\$57.15	<u>7B</u>	<u>1B</u>		<a href="#">View</a>
Klickitat	<a href="#">Surveyors</a>	Instrument Person	\$60.37	<u>7B</u>	<u>1B</u>		<a href="#">View</a>
Klickitat	<a href="#">Surveyors</a>	Party Chief	\$66.09	<u>7B</u>	<u>1B</u>		<a href="#">View</a>
Klickitat	<a href="#">Traffic Control Stripers</a>	Journey Level	\$50.69	<u>7P</u>	<u>1K</u>		<a href="#">View</a>
Klickitat	<a href="#">Truck Drivers</a>	Asphalt Mix Over 10 Yards	\$47.01	<u>5A</u>	<u>1B</u>		<a href="#">View</a>

Klickitat	<a href="#">Truck Drivers</a>	Asphalt Mix To 10 Yards	\$46.87	<u>5A</u>	<u>1B</u>		<u>View</u>
Klickitat	<a href="#">Truck Drivers</a>	Dump Truck	\$46.87	<u>5A</u>	<u>1B</u>		<u>View</u>
Klickitat	<a href="#">Truck Drivers</a>	Dump Truck And Trailer	\$47.01	<u>5A</u>	<u>1B</u>		<u>View</u>
Klickitat	<a href="#">Truck Drivers</a>	Other Trucks	\$47.01	<u>5A</u>	<u>1B</u>		<u>View</u>
Klickitat	<a href="#">Truck Drivers - Ready Mix</a>	Transit Mixers 20 yards and under	\$52.44	<u>5D</u>	<u>1V</u>	<u>8M</u>	<u>View</u>
Klickitat	<a href="#">Truck Drivers - Ready Mix</a>	Transit Mixers over 20 yards	\$52.78	<u>5D</u>	<u>1V</u>	<u>8M</u>	<u>View</u>



## **SPECIAL PROVISIONS**

### **INTRODUCTION**

The following Special Provisions supersede any conflicting provisions of the current Standard Specifications for Road, Bridge, and Municipal Construction and the foregoing amendments to the Standard Specifications and are made a part of this contract.

### **TERMS**

Where the terms "State" or "Contracting Agency" appear in the Standard Specifications and the Special Provision, the "City of White Salmon" shall be used for this contract. Where the terms "Engineer" or "Secretary of Transportation" appear in the Standard Specifications and the Special Provisions, "City of White Salmon" or their "designated representative" shall be used for this contract. Where the terms "Department" or "Department of Transportation" appear in the Standard Specifications and the Special Provisions, "City Council of White Salmon" shall be used for this contract. Where the term "Superior Court" appears in the Standard Specifications and the Special Provision, "Superior Court of Klickitat County" shall be used for this contract.

## **DIVISION 1 GENERAL REQUIREMENTS**

### **DESCRIPTION OF WORK**

The project includes the following approximate major work descriptions, in several separate schedules:

Base Bid: 1200 cyd of excavation, 1038 tons of crushed surfacing, 470 tons of hot mix asphalt, 1,296 syd of pavement grinding, 1580 syd of pavement removal, 1,111 feet of curb and gutter, 265 syd of concrete sidewalk and driveway, 146 feet of 12" storm and 3 catch basins.

### **COORDINATION OF CONTRACT DOCUMENTS, PLANS, SPECIAL PROVISIONS, SPECIFICATIONS, AND ADDENDA**

Section 1-04.2 of the Standard Specifications is modified in part to read:

Any inconsistency in the parts of the Contract shall be resolved by following this order of precedence (e.g., 1 presiding over 2, 3, 4, 5, 6, and 7; 2 presiding over 3, 4, 5, 6, and 7; and so forth):

1. Addenda,
2. Proposal Form,
3. Special Provisions,
4. Contract Plans,
5. Amendments to the Standard Specifications,
6. Standard Specifications, and
7. *Standard Plans.*

On the Contract Plans, Working Drawings, and *Standard Plans*, figured dimensions shall take precedence over scaled dimensions.

### **GENERAL NOTES**

1. The Contractor shall procure and conform to all construction permits required by the City. The Contractor shall pay for all project permit costs. A City business license will be required and approval and proper permitting of dump site will be required before any work begins. Any additional permits needed for all project work to take place will be the contractor's responsibility.
2. All materials and workmanship for facilities in street right of way or easements shall conform to the approving agency's construction specification wherein each has jurisdiction including, but not limited to the City of White Salmon, Washington Department of Health (DOH) and Washington Department of Ecology (DOE).
3. The Contractor shall perform all work necessary to complete the project in accordance with the approved construction drawings and specifications including such incidentals as may be necessary to meet applicable agency requirements and provide a completed project.
4. The Contractor shall notify all utility companies a minimum of 48 business hours (2 business days) prior to start of construction and comply with all other requirements of the serving utilities.
5. Any inspection by the City or other agencies shall not, in any way, relieve the Contractor from any obligation to perform the work in strict compliance with the contract documents, applicable codes and agency requirements.
6. The Contractor shall erect and maintain barricades, warning signs, and traffic cones per city requirements in accordance with the manual on uniform traffic control devices (MUCTD) with Washington amendments. Access to driveways shall be maintained at all times. All traffic control measures shall be approved and in place prior to any construction activity.
7. Contractor shall submit an asbuilt set of plans following construction completion and prior to project acceptance.
8. Material submittals shall be made for all materials used for the project.
9. Other work designated to Project Engineer- Change Orders, Force Account, Cl2 testing, pressure testing, problems with customers and or connections, changes in the field.

### **CONSTRUCTION STAKING**

The Engineer will provide the following:

1. Control points and bench marks on the job site;
2. Offset stakes for curbs, manholes, catch basins, water/sewer/storm lines, and other appurtenances.
3. Location stakes for miscellaneous items.

It shall be the contractor's responsibility to preserve all construction stakes and bench marks. Replacement caused by damage shall be made by the Engineer at the expense of the Contractor.

It shall be the contractor's responsibility to verify the correctness of the CADD drawings prior to staking.

The Contractor shall provide a minimum of 3 working days notice ahead for staking to the Engineer.

## **LEGAL RELATIONS AND RESPONSIBILITIES TO THE PUBLIC**

### **LIABILITY**

The Contractor shall be liable for the payment of all fines and penalties resulting from failure to comply with the federal, state, and local pollution control requirements.

### **LOAD LIMITS**

Legal load limits as described in Section 1-07.3 shall be adhered to.

### **HAULING ON OTHER THAN STATE HIGHWAYS**

If the sources of materials provided by the Contractor necessitate hauling over roads other than State Highways, the Contractor shall, at the Contractor's expense, make all arrangements for the use of the haul routes.

### **TEMPORARY EROSION CONTROL**

The contractor shall perform all temporary water pollution/erosion control measures in accordance with the Storm Water Pollution Prevention Plan (SWPPP), permits and local, state and federal law. The City will obtain the Construction Storm water General Permit. The SWPPP for the project is available upon request.

The contractor shall identify and provide the ESC Lead in accordance with Section 8.01 of the Standard specifications. The ESC Lead shall implement the Plan and all erosion control measures required to conform to state water quality standards.

The ESC Lead will be measured and paid for as per day and shall include all work necessary to install/maintain/remove BMP's in accordance with 8-01 of the standard specifications, monitoring and measuring requirements, submitting all discharge monitoring reports and inspection reports by the 5<sup>th</sup> of the month to the City. ESC lead is included in both the Base and Alternate bids.

### **SPILL PREVENTION CONTROL AND COUNTERMEASURES**

The contractor shall prepare a project specific SPCC Plan in accordance with Section 1-07.15(1) as revised by the amendments. The SPCC Plan shall be paid for as lump sum.

### **UTILITIES**

Section 1-07.17 is supplemented by the following:

#### **EXISTING UTILITIES AND FACILITIES:**

1. The location and descriptions of existing utilities shown on the drawing are compiled from available records and/or field surveys. The Engineer, The City of White Salmon and Utility Companies do not guarantee the accuracy or completeness of such records. The Contractor shall field verify locations and sizes of all existing utilities prior to construction at no expense to the City of White Salmon.
2. The Contractor shall field verify location and depth of all existing utilities where new facilities cross. Contractor shall be responsible for exposing potential utility conflicts far enough ahead of construction to make necessary grade or alignment modifications without delaying the work. If grade or alignment modifications are necessary the Contractor shall notify the Engineer and the Engineer shall obtain approval from the City prior to construction. All utility crossings shall be potholed as necessary prior to excavating or boring to allow the contractor to prevent grade or alignment conflicts.
3. All facilities shall be maintained in-place by the Contractor unless otherwise shown or directed. Contractor shall take all precautions necessary to support, maintain or otherwise protect existing utilities and other facilities at all times during construction. The Contractor is to leave existing utilities in an equal or better than original condition and to the satisfaction of the City.
4. Waterlines and other utilities or interfering portions of utilities that are to be abandoned in place shall be removed by the contractor to the extent necessary to accomplish the work. The Contractor shall plug the exposed ends of all abandoned utilities with a manufactured plug or concrete.
5. The Contractor shall remove all signs, mailboxes, fences, landscaping, etc. As required to avoid damage during construction and replace them to existing or better condition.
6. Any septic tanks encountered during construction shall be pumped out. Contractor shall break the tank and backfill with pea gravel unless otherwise required by public agencies having jurisdiction. Septic tank removal shall be in accordance with county sanitarian requirements. The Contractor shall coordinate and pay all costs associated with removing or abandoning septic tanks. The Contractor shall notify the City upon discovery of tanks not shown on the plans and obtain concurrence from the City prior to proceeding with the work. The Contractor shall provide a detailed cost breakdown of all work related to said removal or abandonment. The Contractor will be reimbursed on a time and materials basis or at a negotiated price as agreed to by the City.
7. The Contractor shall be responsible for managing construction activities to ensure that public streets and right of ways are kept clean of mud, dust or debris. Dust abatement shall be maintained by adequate watering of the site by the Contractor. Streets shall be swept by the contractor as necessary to keep clean
8. All existing or constructed manholes, cleanouts, monuments, gas valves, water valves and similar structures shall be adjusted to match finish grades of the pavement, sidewalk, landscape area or median strip wherein they lie. Verify that all valve boxes and risers are clean and centered over the operation nut. Adjustment after placement of the final asphalt course will not be allowed.

**UNLOCATED OR MISLOCATED UTILITIES:**

1. Any cost incurred by the Contractor due to un-located or mis-located utilities, including but not limited to city waterlines (mains and services). City sewer lines (mains and side sewers), city storm drains, electrical lines, gas lines, telephone lines, cable television lines shall not be the responsibility of the City and no payment from the City shall be forthcoming for any work related to these un-located or mis-located utilities. The Contractor shall include any cost associated with this item in other items of work.

Locations and dimensions shown in the Plans for existing facilities are in accordance with available information obtained without uncovering, measuring or other verification.

Public and private utilities, or their contractors, will furnish all work necessary to adjust, relocate, replace, or construct their facilities unless otherwise provided for in the Plans or these Special Provisions. Such adjustment, relocation, replacement or construction will be done during the prosecution of the work for the project.

The Contractor shall call the Utility Location Request Center (One Call Center), for field location, not less than two, nor more than ten business days before the scheduled date for commencement of excavation which may affect underground utility facilities, unless otherwise agreed upon by the parties involved. A business day is defined as any day other than Saturday, Sunday, or a legal local, State or Federal Holiday. The telephone number for the One Call Center is 1-800-424-5555. If no one-number locator service is available, notice shall be provided individually to those owners known to or suspected of having underground facilities within the area of proposed excavation.

The Contractor is alerted to the existence of Chapter 19.122 RCW, a law relating to underground utilities. Any cost to the Contractor incurred as a result of this law shall be at the Contractor's expense.

No excavation shall begin until all known facilities, in the vicinity of the excavation area, have been located and marked.

The following addresses and telephone numbers of utility companies known or suspected of having facilities within the project limits are supplied for the Contractor's convenience:

Water/Sewer/Street	City of White Salmon	Fred Simonson	509-493-1137
Telephone	Embarq	Bill Muncey	541-387-9346
Power	Klickitat PUD	Mike Blumenstein	509-493-2255
Gas Pipeline	Northwest Natural	Sheri Clark	503-226-4211ext.2045
Cable	Charter Communications	Mark Voorde	509-731-0272

## **PUBLIC LIABILITY AND PROPERTY DAMAGE INSURANCE**

In addition to the requirements of Section 1-07.18, the Contractor shall comply with the following:

The cost to name the State as being insured as required by Section 1-07.18 shall be reported to the Engineer on DOT Form 421-025, Public Liability And Property Damage Insurance Certification. This certification shall identify only the cost to provide insurance coverage for the State in accordance with Section 1-07.18 and shall not include any cost for the Contractor's portion of the insurance. The Contractor shall make every effort to identify the cost. However, in the event the cost is not identifiable, the Contractor will be permitted to report that fact in order to comply with the requirements of this subsection. The certification shall be submitted to the Engineer as soon as the cost can be identified but not later than when the Contractor signs and returns the Final Contract Voucher Certification for final payment as provided in Section 1-09.9. This certification shall be subject to audit, in accordance with Section 1-09.12, to ensure the costs are properly reported.

## **WORK ADJACENT TO PRIVATE PROPERTY**

The Contractor shall conduct his work in such a manner as to minimize the inconvenience to the public, traffic, and property owners.

The Contractor shall confine his operations to easements and public rights-of-way. Where the Contractor is installing improvements on private property, he shall keep his operations to a minimum.

The Contractor must provide the 48-hour prior notice to the Owner before entering upon private property. Upon the completion of each day's work, the Contractor shall make provisions as may be required to ensure access by all property owners to their property. The Contractor must backfill all pipe ditches along roadways at the end of each day. Without prior approval from the Engineer, not more than 200 feet of ditch can be open at any time. In areas where rock is encountered and it is not feasible to backfill the ditch at the end of the day, a barrier acceptable to the Engineer shall be placed along the open trench.

The Contractor shall prevent dust nuisance by applying water as necessary, and also at times and in locations required by the Engineer. Water shall be included in other items of work and no separate payment shall be made.

## **SAFETY AND HEALTH**

The Contractor shall comply with Safety and Health, Health Regulations for Construction, promulgated by the Secretary of Labor under Section 107 of the Contract Work Hours and Safety Standards Act, as set forth in Title 29, C.F.R. Copies of these regulations may be obtained from Labor Building, 14th and Constitution Avenue NW, Washington, DC 20013.

The Contractor shall also comply with the provisions of the Federal Occupational Safety and Health Act, as amended, and all applicable state and local laws, regulations, and codes related to safety and health and Washington State Safety Standards for Construction work (Chapter 296-155 WAC as issued 5/00).

## **NOISE POLLUTION**

The Contractor shall take all reasonable measures for the suppression of noise resulting from work operations consistent with the applicable local regulations regarding noise control levels.

Mobile engine driven cranes, loaders, and similar material handling equipment; engines used in stationary service for standby power; and air compressors from high and low pressure service shall be equipped with exhaust and air intake silencers designed for the maximum degree of silencing. The type of silencer required is that specified by the applicable noise regulations for use in critical noise problem locations such as high density residential, hotel, and hospital areas.

## **PUBLIC CONVENIENCE**

The Contractor shall conduct his work in such a manner as to minimize the inconvenience to the public, traffic, and property owners.

The Contractor shall confine his operations to easements and public rights-of-way. Where the Contractor is installing improvements on private property, he shall keep his operations to a minimum. Work during weekdays shall be between 7 am and 7 pm. Work on weekends shall be between 8 am and 5 pm.

The Contractor must provide the 48-hour prior notice to the Owner before entering upon private property. Upon the completion of each day's work, the Contractor shall make provisions as may be required to ensure access by all property owners to their property. The Contractor must backfill all pipe ditches along roadways at the end of each day. Without prior approval from the Engineer, not more than 200 feet of ditch can be open at any time. In areas where rock is encountered and it is not feasible to backfill the ditch at the end of the day, a barrier acceptable to the Engineer shall be placed along the open trench.

The Contractor shall prevent dust nuisance by applying water as necessary, and also at times and in locations required by the Engineer.

### **PROJECT TEMPORARY TRAFFIC CONTROL**

The Contractor shall use the Construction Signing and Traffic Control Plan provided. Any alternate request for Construction Signing and Traffic Control Plan must be submitted to the City and approved prior to start of construction and any work in the public right-of-way.

The Contractor shall notify the City a minimum of 72 hours in advance of any construction requiring partially closing the road. Access may require temporary sheeting.

The Contractor shall take all necessary measures to maintain a normal flow of vehicular and pedestrian traffic to prevent accidents and to protect the work throughout the construction stages until completion of the work. The Contractor shall make the necessary arrangements to reroute traffic, provide and maintain barriers, cones, guards, barricades, and construction warning and regulatory signs. The Contractor shall take effective measures necessary to protect all other portions of the work during construction and until completion. This includes providing and maintaining all necessary barriers, barricade lights, guards, temporary crossovers, and watchmen in accordance with the "Manual on Uniform Traffic Control Devices for Streets and Highways," U.S. Department of Transportation, Federal Highway Administration. Failure to comply will be cause for the project to be temporarily shut down until corrections are made.

The Contractor shall daily clean up areas exposed to traffic and place type II barricades, lights and reflective cones that are fully functioning at the end of each shift.

Project Temporary Traffic Control shall be paid by lump sum. Traffic control devices, supervisor, flagging, and all Class A construction signing necessary shall be included in this item.

### **PROGRESS SCHEDULING**

At the pre-construction conference, the Contractor shall furnish to the Engineer a construction schedule, which shall be mutually agreed upon. Any subsequent substantial changes in the Contractor's schedule shall be submitted to the Engineer for his approval.

Five percent (5%) withheld in accordance with Section 1-09.9(1) of the Standard Specifications.

### **REQUIREMENTS ON COUNTY ROADS**

The Contractor shall comply with all requirements of the Klickitat County Department. The Contractor shall not be allowed to haul on the County road rights-of-way during the winter months, except as determined by the County Road Departments.

### **DISPOSAL OF SURPLUS MATERIAL**

No disposal site is provided. The contractor shall make all arrangements for disposal. Landowner approval and required permits must be given to Engineer prior to Excavation.

### **MATERIALS SOURCE**

No source has been provided for any materials necessary for the construction of this improvement. The Contractor shall make arrangements to obtain the necessary materials at no expense to the City, and all costs of acquiring, producing, and placing this material in the finished work shall be included in the unit contract prices for the various items involved.

### **RESTORATION OF IMPROVEMENTS**

The Contractor shall remove such existing structures, including signs, curbs, gutters, pipelines and utility poles, as may be necessary for the performance of the work and shall rebuild the structures thus removed in as good a condition as found with the requirements specified. He shall also repair existing structures which may be damaged as a result of the work under this contract.

Cultivated or planted areas and other surface improvements which are damaged by actions of the Contractor shall be restored as nearly as possible to their original condition. Landscaping areas will need to be widened where sidewalk locations shift. Materials will match those behind the existing adjacent walk. Additional plants will not be required unless separately contracted for with the adjacent landowner.

Existing culverts, guard posts, barricades, mailboxes and fences shall be protected and replaced if damaged.

The Contractor shall immediately correct or replace existing equipment, controls or systems which are damaged as a result of his operations.

The Contractor shall restore or replace in kind damages to private property, public or private utilities, or the Owner's property caused by his operations. All areas outside the limits of the work that have been disturbed by the Contractor shall be smoothed, reshaped, and restored to conform to the surrounding undisturbed areas. All areas shall be cleaned up in a workmanlike manner free of litter, debris, and excess materials.

The Contractor shall plan his operation, equipment, and materials storage so they do not unreasonably limit accessibility of City and Klickitat County personnel, and other persons in the construction area.



The Contractor shall be solely responsible for any trespass on adjacent property or injury thereto resulting from or in connection with his operations. He shall hold the Owner harmless from any claims that may result because of his trespass or the deposit of debris upon adjacent property.

No separate measurement or payment will be made for restoration of improvements which are considered incidental to other items or work.

### **CONSTRUCTION SITE CONTROLS**

The contractor shall keep the work site clean and free from rubbish and debris. Materials and equipment shall be removed from the site when they are no longer necessary. Upon completion of the work and before final acceptance, the work site shall be cleared of equipment, unused materials and rubbish to present a clean and neat appearance.

The Contractor shall not discharge smoke, dust, and other contaminants into the atmosphere that violate the regulations of any legally constituted authority. He shall also abate dust nuisance by cleaning, sweeping, and sprinkling with water, or other means as necessary. The use of water, in amounts which result in mud on public streets is not acceptable as a substitute for sweeping or other methods.

### **CLEARING AND GRUBBING**

Clearing and grubbing on this project shall be performed in accordance with Section 2-01. No separate measurement or payment will be made for clearing and grubbing on this project, it being considered incidental to construction, and payment therefore being included in other items of work.

### **PLANING BITUMINOUS PAVEMENT**

Section 5-04.3(14) is supplemented with the following:

All planed material shall be hauled to the City Maintenance Yard and distributed at the direction of the Public Works Supervisor.

Care shall be taken to not damage the valve boxes while adjusting them. Valve boxes damaged, due to the Contractor's operations, shall be repaired or replaced by the Contractor at no additional cost to the Contracting Agency and to the satisfaction of the Engineer.

Section 5-04.4 is supplemented with the following:  
Measurement shall be for actual square yards planed.

Section 5-04.5 is supplemented with the following:  
Payment will include all costs associated with planing surface, excavating material, loading, hauling material and depositing material for City forces to grade.

### **ASPHALT REMOVAL**

Section 2-02.3(3) is supplemented with the following:

Care shall be taken to not damage the valve boxes while adjusting them. Valve boxes

damaged, due to the Contractor's operations, shall be repaired or replaced by the Contractor at no additional cost to the Contracting Agency and to the satisfaction of the Engineer. Measurement shall be for actual square yards removed.

The unit cost shall include all costs associated with asphalt removal, excavating material, loading, hauling and depositing material at an approved disposal site.

### **BALLAST AND CRUSHED SURFACING**

Ballast and Crushed Surfacing for top course and base course shall be in accordance with Section 4-04 and 9-03 of the Standard Specifications

Crushed surfacing under the following surfaces: Concrete driveways and sidewalks shall be included in those items and no separate payment will be made.

Base course under roadway shall be paid per ton.

Top course under roadway shall be paid per ton.

Weigh tickets for crushed surfacing will be collected by the inspector on site for each load.

The unit price for crushed surfacing base course, hauling, placing, watering, compacting, and all other work as specified.

### **SURFACE RESTORATION**

The Contractor shall perform all work and furnish all materials to restore any gravel, asphalt, or concrete surface damaged or disturbed by his construction operation. The Contractor shall be responsible for maintaining a road surface suitable for travel by the public from the time of excavation until the road surface has been restored. Such work includes dust control, temporary patching, curb replacement, signing, grading, matching to existing driveways and alleys, and filling of potholes on temporary street surfaced, etc. The Contractor shall be responsible for all claims and damages resulting from his failure to maintain a suitable surface.

All surfaces and surface improvements affected by the Contractors' operations shall be restored to a condition equal to or better than pre-construction conditions. The Engineer shall be the sole judge as to the equality of materials and work when comparing post-construction conditions to pre-construction conditions. Restoration shall be fully completed within two weeks after backfilling is done.

Surface restoration of earth areas and slopes shall consist of the removal of rocks larger than 3" from the top 3" of the backfill and replacement of topsoil (Type B) in accordance with Section 9-14. It is recommended that the topsoil be kept separated during excavation. Grass seed shall be mixed as follows and applied with an approved hydroseeder or as an option with seed and mulch:

Fairway, Douglas, or Ephraim-Crested Wheat Grass	12.5#/acre
Arriba, Barton or Rosana-Western Wheat Grass	12.5#/acre
Durar-Hard Fescue	12.5#/acre
Covar, Azay, MX-86, Mechlenberg-Sheep Fescue	12.5#/acre
Fertilizer (26-13-13)	385#/acre
Mulch	1400#/acre

Hot Mix Asphalt (HMA) shall conform to Section 5-04 of the Standard Specifications for commercial HMA. A mix design shall be submitted for approval.

Surface restoration for asphalt areas shall be paid for by the ton for HMA surfacing.

The maximum pay width for HMA surfacing shall be 4.00 feet unless approved otherwise.

Extra excavation in those areas exceeding the limits will not be allowed. Disturbing areas of existing asphalt outside of these limits will result in asphalt replacement without compensation.

Surface restoration for gravel areas, grass areas, slopes, ditches and all other work not specified shall be paid per lump sum of the surface restoration bid item.

### **EXCAVATION AND EMBANKMENT**

Excavation and embankment shall conform to Section 2-03 of the Standard Specifications.

Only one determination of the original ground elevation will be made on this project. Measurement for excavation will be based on the original ground elevations determined during the topographic survey. Control stakes will be set during construction to provide the Contractor with all essential information for the construction of excavation and embankments.

If discrepancies are discovered in the ground elevations which will materially affect the quantities of earthwork, the original computations of earthwork quantities will be adjusted accordingly.

Earthwork quantities may be computed by means of electronic data processing equipment.

The excavation of existing sidewalks, driveways, and curb and gutters is included in this item. All costs associated with removal, loading,

Copies of all survey data and calculations of quantities will be available to the contractor.

The unit contract price per cubic yard for excavation and grading for roadway, including hauling shall include all materials, tools, labor, work, and equipment necessary for excavation to the grade lines shown including but not limited to hauling, shaping, and grading per section 2-03, subgrade preparation per section 2-06, compacting, testing, and loading.

### **TRENCH EXCAVATION, BEDDING AND BACKFILL**

Trench excavation, bedding and backfill shall be done in accordance with Section 7-08 and 7-09 of the Standard Specifications.

Bedding material shall be gravel backfill for pipe zone bedding per Section 9-03.12(3) of the Standard Specifications.

All trenches shall be backfilled or plated at the end of each day. No trench will be left open at night or on weekends.

Trench backfill shall be in accordance with the trenching details. The Contractor shall have the option of using CDF in lieu of crushed surfacing. Crushed surfacing shall be compacted to 95%. The Contractor shall provide compaction tests to verify that backfill meets the 95% density requirements. Any areas not meeting the requirements shall be removed and re-compacted.

CDF shall meet the requirements of Section 2-09.3(1)E of the Standard Specifications.

Bedding material and backfill material will be approved by the Engineer.

Trench excavation, bedding material, backfill and CDF shall be included in the linear foot price for piping or other related items of work and no separate payment will be made therefore.

In those areas where CDF is required by the Engineer, payment will be by the cubic yard. No adjustment for decreases in quantities will be made since this item is designated as a common proposal in accordance with Section 1-04.6.

### **REMOVAL OF STRUCTURES AND OBSTRUCTIONS**

This Item shall comply with Sections 2.02 and of the Standard Specifications.

This work consists of removing, handling, and disposing of material and debris encountered during excavation for roadway, trench, or sidewalks. This bid item is to include any existing pipes, thrust blocks, utilities, structures for utilities, manholes, catch basins, riprap, buried concrete, logs or debris, asphalt pavement, existing concrete or rock walls, fences, landscape items, and any other structures or obstructions that must be removed to complete the project as shown on the Plans and detailed in these contract provisions. Any salvageable materials or items shall be delivered to the City.

Removal of structures and obstructions shall be paid for by lump sum.

### **EXTRA TRENCH EXCAVATION**

Extra trench excavation required by changes in grade shall be in accordance with Section 7-09.3(7) of the Standard Specifications and shall include replacement with suitable backfill. Known locations where more than 3' of cover is required due to conflict with existing or future utilities is specified on the plans.

Extra excavation will be paid for by the cubic yard, in place, additional rock required, and all include hauling. There shall be no adjustment for decreases in quantities since this item is designated as a common proposal in accordance with Section 1-04.6.

### **REMOVAL AND REPLACEMENT OF UNSUITABLE TRENCH & FOUNDATION MATERIAL**

Unsuitable Material below the bottom of the trenches and foundations shall be removed to the depth directed by the Engineer and backfilled and foundation material in accordance with Section 2.03.3(14)E and 7-09.3(8) of the Standard Specifications.

Where unsuitable trench and foundation excavation is required, payment shall include replacement with suitable backfill.

Removal and replacement of unsuitable foundation & extra trench excavation shall be paid for by cubic yard, in place, and include hauling and there shall be no adjustment for decreases in quantities since this item is designated as a common proposal in accordance with Section 1-04.6.

### **SHORING**

Shoring shall comply with Section 2-09.5 and 7-08.3(1)B of the Standard Specifications and shall be paid for per lump sum.

### **ROCK EXCAVATION**

Rock excavation shall be in accordance with Section 7-09.3(7)B of the Standard Specifications.

In addition to the requirements of the Standard Specifications, the following shall also apply:

The Contractor shall give 24 hour notification to the City, White Salmon Police Department, and all property owners within 500 feet of the blast area at least 24 hours prior to any blasting operations. Blasting shall be done in accordance with Safety and Health regulations of the State of Washington.

Rock excavation shall be paid for by the cubic yard. No adjustment in the bid price for decreases or increases will be made since this item is designated as a “common proposal” in accordance with Section 1-04.6.

The transportation, handling, storage, and use of explosives shall be subject to the provisions of Page 287 of Subpart U, Blasting and the use of Explosives, Section 1518.900, General Provisions of the Department of Labor, “Safety and Health Regulations for Construction,” and applicable provisions of the Bureau of Reclamation Supplement thereto and the State of Washington Department of Labor and Industries “Safety and Health Regulations for Construction Work” WAC 296, Chapter 40, pages 330 through 400. The Contractor shall maintain an inventory record of storage and withdrawal of all explosives. This record shall be available to the Engineer and he shall promptly be notified of any loss or theft of explosives. The Contractor shall provide such reasonable and adequate protective facilities as are necessary to prevent loss or theft of explosives. Overnight storage of explosives and detonators outside of the magazines will not be permitted.

When drilling in rock or other dust producing material, the dust shall be controlled within the safe hygienic limits as specified in the “Threshold Limit Values of Airborne Contaminates” published by the American Conference of Governmental Industrial Hygienists.

All percussion-type drilling shall be performed with drilling apparatus equipped with water or chemical dust-control systems or other equivalent means of controlling the dust. Pressure tanks used in the suppression equipment shall conform to ASME Boiler and pressure Vessel Code. Section VII for Unfired Pressure Vessels. Equipment and solution used shall be suitable for operation in freezing weather. Dust-control devices are not required on jackhammers, provided the operators wear approved-type dust respirators when dust concentrations exceed safe hygienic limits.

Since the excavation and blasting operations are adjacent to private improvements, the Contractor shall take adequate precautions to fully protect all property from damage caused by blasting operations. All blasting shall be carried out in such a manner as to minimize vibrations that reach adjacent structures, and the Contractor shall take such precautions to ensure that such vibrations as recorded at the nearest buildings or structures are not of such magnitude as to cause damage.

Flyrock shall be controlled through proper spacing of the charges and through the use of blast mats or mounding soil over the shot after loading.

Removal of rock by hammering will be allowed. The Contractor shall be responsible for testing (by a licensed laboratory) of the rock to determine if it meets the definition of Section 7-09.3(7)B of the Standard Specifications if any disagreements arise as to what constitutes rock.

### **REPAIR WATERLINE**

Existing water mains and services shall be maintained at all times. Damaged lines shall be repaired by the contractor at no cost to the City.

### **STORM SEWER**

Storm sewers shall be 12" corrugated smooth interior polyethylene pipe, as specified in Sections 7-04 and 9-05.20 and constructed in accordance with Section 7-08 of the Standard Specifications and the plans. Once a particular type and manufacturer is selected the contractor shall use that type for the entire project. In areas where not under new roadway construction, all backfilling will be done according to the trenching details shown on the plans and will be included in this pipe price.

Excavation, bedding and backfill for storm sewer shall be as shown and payment shall be considered as included in the linear foot price for storm sewer.

Manhole covers shall contain the word "STORM" in 2" raised letters. Manholes shall conform to Section 7-05. Manholes shall be installed over 6 inches of bedding material. All lift holes must be grouted from the outside of the manhole prior to backfilling. Manhole rims in paved areas or shoulders shall be installed flush with the pavement. All pipe connections into new manholes shall be installed with an approved entry coupling or gasket.

Manholes shall be measured by each for each type installed. The unit price bid per each manhole shall be full compensation for the manhole in place complete, including; new or salvaged frames and covers, connections to sewer pipes, excavation, backfill, removal and disposal of existing manhole (where required), testing, and all incidental work required for a complete facility.

### **CATCH BASIN**

Catch Basins shall conform to Section 7 of the Standard Specifications. Catch basins in streets shall be either concrete catch basins or Nyoloplast Catch basins. Once the contractor has decided on the type they shall be used throughout the project. Concrete catch basins bases may be either precast or cast in place conforming to WSDOT Type I, in accordance with Standard Plan B-1 and B-2e. Catch basins shall be backfilled with approved ¾" crushed rock.

Locations of combination Inlets with a curb opening grate or flat grade inlets will be specified on the plans. Flat grate inlet shall conform to Standard Plan B-2b.

The unit price bid per each, for either Catch Basin - Combination Inlet, shall include the frame and grate, insert debris trap, excavation, backfill and all costs for furnishing the catch basins completed and placed.

The unit price bid per each, for either Catch Basin – Type I, Flat grate Inlet, shall include the frame and grate, insert debris trap, excavation, backfill and all costs for furnishing the catch basins completed and placed.

### **COMPACTION TESTING**

The contractor shall provide compaction tests for trench backfill and for compaction of base and top course and for Hot Mix Asphalt. A plan for compaction testing shall be submitted for approval.

The plan shall outline the number of compaction tests required for trenching and for the layers of top course and ballast to satisfactorily guarantee that the requirements for compaction are met. If testing indicates failure to comply with the requirements additional tests will be required at no cost.

Compaction testing will be required under all roadways and ditches every 300 feet. If testing indicates failure to comply with the requirements additional tests will be required at no cost.

Maximum density and optimum moisture content shall be in accordance with Section 2-03.3(14)D of the Standard Specifications and shall be done by an independent testing laboratory and shall be submitted to the Engineer prior to any compaction tests. Written compaction tests results from an independent testing laboratory must be received within 48 hours of the test and prior to placing asphalt pavement.

Compaction testing shall be included in other items of work and no separate payment shall be made.

### **WORK BREAKDOWN BY SCHEDULE**

Note: The following work descriptions are general and intended to give the contractors a basic idea of the work divisions between schedules. Contractors are advised that changes to the specifications may be made by addendum, and receipt and understanding of each addendum must be shown on the bid sheet. Failure to certify receipt and inclusion of addendums may result in bid rejection.

**OTHER CONTRACTORS:** It is expressly understood that more than one contractor may be working on the site, and that each contractor must cooperate and communicate with the other contractors so that no delays or conflicts arise. The work and presence and reasonable adjustment of schedules to allow for work by other contractors is a part of the work description and shall not be the basis for any claim against the City of White Salmon.

**GENERAL STANDARDS:** It is understood that provision and appropriate installation of materials and equipment are included in each Schedule unless specifically exempted or listed as work elsewhere. At a minimum, all work must meet the Contract Specifications, the International Building Code, WSDOT Standard Specifications, the National electrical Code and the manufacturer's recommendations. All work shall be tested for compliance with specifications and shall pass the various tests prior to acceptance by the City.

**SUBMITTALS:** The Contractor must submit for approval, prior to ordering, three (3) copies of any and all manufactured equipment or material. This includes, AT A MINIMUM, all piping, fittings, valves, valve boxes, control valves, and additional equipment necessary for the construction of a complete project.

Coordination will be critical when new mainline is brought in use to eliminate shut down of water service to customers for longer than 8 hours. All customers will need to be notified when this will take place.

### **HOT MIX ASPHALT (HMA)**

Hot Mix Asphalt on this project will be performed under the following revisions to the Standard Specifications.

Delete Section 5-04.3(8)A Acceptance Sampling and Testing HMA

Delete Section 5-04.3(10)B Control, and replace with the following:

HMA used in traffic lanes, including lanes for ramps, truck climbing, weaving and speed change, and having a specified compacted course thickness greater than 0.10 foot, shall be compacted to a specified level of relative density. The specified level of relative density shall be a Composite Pay Factor (CPF) of not less than 0.75 when evaluated in accordance with section 1-06.2, using a minimum of 91.0 percent of the reference maximum density as determined by WSDOT FOP for AASHTO T 209. The reference maximum density shall be determined as the moving average of the most recent five determinations for the HMA being placed. The specified level of density attained will be determined by the statistical evaluation of five nuclear density gauge test taken in accordance with FOP for WAQTC TM 8 and WSDOT SOP T 729 on the day the mix is placed (after completion of the finished rolling) at locations determined by the stratified random sampling procedure conforming to WSDOT Test Method No. 716 within each density lot. The quantity represented by each density lot will be no greater than a single day's production or 400 tons, whichever is less. The final lot each day may be increased to a maximum of 600 tons.



Control lots not meeting the minimum density standard shall be removed and replaced with satisfactory material. At the option of the Engineer, non-complying material may be accepted at a reduced price.

Cores may be used as an alternate to the nuclear density gauge tests. When cores are taken by the Engineer at the request of the Contractor, the request shall be made by noon of the first working day following placement of the mix. The Engineer shall be reimbursed for the coring expenses at the rate of \$250 per core when the core indicates the acceptable level of compaction within a lot has not been achieved.

A tack coat will be applied to the edge of the asphalt cut prior to paving. No slurry seal will be used.

Prior to the start of production paving the contractor shall notify the PE that a test section is requested and will be constructed. The compaction test section may be constructed simultaneously with the HMA mixture test section.

The test section, if requested, shall be constructed at the beginning of production paving, and shall be done using the equipment and rolling pattern that the Contractor expects to use in the paving operation. The compaction test section will be a maximum of 800 tons. A test section will be considered to have established that the mix is compactable when the average of the three tests exceeds 92.0 percent of the maximum density determined by WSDOT FOP for AASHTO T 209 or when each of the three tests exceeds 91.0 percent.

HMA constructed under conditions other than those listed above in paragraph "1. General" shall be compacted on the basis of a test point evaluation of the compaction train. The test point evaluation shall be performed in accordance with instructions from the Project Engineer. The number of passes with an approved compaction train, required to attain the maximum test point density, shall be used on all subsequent paving.

In addition to the randomly selected locations for tests of the density, the Project Engineer may also isolate from a normal lot any area that is suspected of being defective in relative density. Such isolated material will not include an original sample location. A minimum of five randomly located density tests will be taken. The isolated area will then be statistically evaluated as a separate lot and a CPF so determined.

Acceptance testing for compliance of asphalt content will use the Nuclear Asphalt Gauge Procedure; WSDOT Test Method 722-T. Acceptance testing for compliance of gradation will use the Quick Determination of Aggregate Gradation Using Alternate Solvent Procedure: WSDOT Test Method 723-T.

Delete Section 5-04.5(1) – Quality Assurance Price Adjustment  
Delete Section 5-04.5(1)A – Price Adjustments for Quality of HMA  
Delete Section 5-04.5(1)B – Price Adjustments for Quality of HMA Compact

Add the following paragraph of Section 9-03.8(6):

For the determination of a Project Mix Design, the Contractor shall submit to the Engineer's representative, a recent (24 month max.) approved mix design which will be reviewed for acceptance in accordance with 5.04.3(7)A-3.

Tonnage tickets must be presented to inspector with each load. Any portion of any load that is taken back to the plant, removed from the project site, or rejected will be deducted from the tonnage ticket. Partial loads taken back will be reweighed with a corrected tonnage ticket to be presented to the inspector. New HMA temporary ramps that are removed will be paid for at the discretion of the engineer.

HMA surfacing will be paid for by the ton.

### **CONCRETE CURB AND GUTTER**

The cement concrete curb and gutter shall be constructed in accordance with section 5-05, 6-02, and 8-04 of the Standard Specifications and as further described in the Plans. All curbs and gutters shall be constructed with air entrained concrete Class 4000.

Curing shall be performed by applying a colorless sealing compound to the surface of the concrete immediately after it has set sufficiently to permit such application. Curing compound shall meet the requirements of Section 9-23.2 except that it shall be colorless. Curing compound shall be approved by the Engineer.

Mastic expansion joints shall be placed at all points of tangency and matching sidewalk joints.

No concrete shall be poured against dry forms or dry subgrade.

Concrete cylinders will be taken by the Engineer each day.

All completed work shall be so barricaded as to prevent damage by unauthorized use. Any damaged sections shall be removed and replaced at the Contractor's expense.

The unit price bid shall include all labor and materials necessary to forming, placing, buck-outs, depressed sections, joint fillers, curing, barricades, reinforcement, and any other items of cost necessary to the installation, complete in place.

Measurement for payment will be the lineal foot of curb or curb and gutter in place, and measurement will be made along the back line of the curb.

### **SIDEWALK AND DRIVEWAY APRONS**

Sidewalks and driveway aprons shall be constructed in accordance with section 5-05, 6-02, 8-06, and 8-14 of the Standard Specifications and as further described herein and shown on the Plans.

All driveways shall be constructed with air entrained concrete Class 4000, sidewalks will be allowed to meet class 3000.

Mastic expansion joints shall be placed at all points of tangency and matching sidewalk joints.

No concrete shall be poured against dry forms or dry subgrade.

Concrete cylinders will be taken by the Engineer each day.

Curing shall be performed by applying a colorless sealing compound to the surface of the concrete immediately after it has set sufficiently to permit such application. Curing compound shall meet the requirements of Section 9-23.2 except that it shall be colorless. Curing compound shall be approved by the Engineer.

All completed work shall be so barricaded as to prevent damage by unauthorized use. Any damaged sections shall be removed and replaced at the Contractor's expense.

Premolded joint filler shall be 3/8 inch thick shall be placed 15 foot on center and the beginning and end of any curve. Dummy joints shall be at 5'0" intervals. Sidewalk and curb joints shall coincide. Joint filler shall be placed between all new work and existing sidewalks, structures, etc. The cost of this premolded joint filler shall be merged in the unit prices bid for Sidewalks.

The unit price bid per square yard for Sidewalk shall include all costs for furnishing the sidewalks complete in place including excavation, embankment, 2" dead rolled leveling top course material and work, forming around meter boxes, mail boxes or other obstructions and all other work necessary.

The unit price bid per square yard for driveway apron shall include all costs for furnishing the driveways complete in place including excavation, embankment, 2" dead rolled leveling top course material and work, forming around meter boxes or other obstructions, and all other work necessary.

Where stairs or other existing concrete is connected to the current sidewalk, the Contractor shall reconnect them

### **CURB RAMP**

Curb ramps shall be provided as shown on the plans and shall fully comply with ADA requirements as possible.

The unit price bid per each for Curb Ramps shall include only the extra labor and any other special materials (including pedestrian curb) required to form and finish the ramp. Installation shall result in drainage to existing structures and failure to achieve acceptable drainage will result in modification at the contractor's expense.

All costs of concrete, compaction, etc. will be paid under the unit prices for sidewalk.

### **REINFORCED PEDESTRIAN CURB CONCRETE WALL**

Reinforced concrete walls shall be constructed in accordance with section 6-11 of the Standard Specifications. The cubic yard price shall include, but not be limited to excavation, bedding, backfill, concrete, and reinforcement.

## **PEDESTRIAN CURB**

Cement concrete pedestrian curb shall be in accordance with 8-04 of the Standard Specifications and the plans. Pedestrian curb shall be installed as shown on the plans and details.

Pedestrian curb shall be included in other items of work such as curb ramps, sidewalk and driveway aprons and no separate payment shall be made.

## **RESET TRAFFIC SIGNS**

Existing signs will be removed and reset with existing posts as shown and directed.

The price per each should include all work to remove, install and materials, including the foundations and posts. Replacement of existing signs and posts that are damaged will be furnished by the City.

## **ADJUST COVERS AND GRATES TO GRADE**

Manhole covers, catch basin grates, clean outs, valve covers and meter boxes shall be adjusted to finished grade in accordance with 7-05 of the Standard Specifications. This item is only for existing covers, meter boxes and grates that will not be replaced during construction.

Payment will be made per each and includes all materials and work required to adjust each.

## **PAVEMENT MARKINGS**

Pavement markings shall be in accordance with Section 8-22 of the Standard Specifications. The Contractor shall provide temporary markings as required during the phasing of the construction. The cost for any temporary markings shall be included in other items of work.

Crosswalk lines will be paid for as Painted Crosswalk Line, per linear foot at a 1' width.

Centerline lines will be paid for as Painted Line, per linear foot at a 4" width.

## **RELOCATE FENCE**

Existing fences identified on the plans will be removed and reset with existing posts, rails and wire as shown and directed. Fences to be relocated are within the right of way and are of varying types.

The price per linear foot should include all work to remove and relocate, including the existing wire, rails and posts. Additional material needed, will be paid for in compliance with Section 1-09.6 (2) of the Standard Specifications.

## **SAWCUTTING**

Where shown on the Plans or where directed in the field by the engineer, the Contractor shall make a neat vertical saw-cut at the boundaries of the area to be removed. Care shall be taken during sawcutting so as to prevent damage to the existing asphalt concrete, or concrete, to remain in place. Any pavement or concrete damaged by the contractor outside of the area scheduled for removal due to the Contractors operations or negligence shall be replaced and repaired by the Contractor at no additional cost to the City. All saw cuts shall be continuous and full depth at locations approved of by the engineer.

All costs associated with sawcutting shall be included in other items of work.

## **GEOTEXTILE**

Geotextile fabric for stabilization shall be Mirafi 600X or equal.

The manufacturer's certificate of compliance shall include the following information about each geotextile roll to be used:

Manufacturer's name and current address  
Full product name  
Proposed geotextile uses(s)

If the manufacturer of the proposed geotextile(s) has not previously submitted a geotextile for initial source approval for the proposed use and obtained approval, a sample of each proposed geotextile shall be submitted to the Engineer.

The geotextile samples shall be cut from the geotextile roll with scissors, sharp knife, or other suitable method which produces a smooth geotextile edge and does not cause geotextile ripping or tearing. The samples shall not be taken from the outer wrap of the geotextile roll nor the inner wrap of the core.

Acceptance will be by manufacturer's certificate of compliance, submitted with a sample of each geotextile roll to be used:

The manufacturer's certificate of compliance shall include the following information about each geotextile roll to be used:

Manufacturer's name and current address  
Full product name  
Geotextile roll number  
Proposed geotextile uses(s)  
Certified test results

During periods of shipment and storage, the geotextile shall be kept dry at all times and shall be stored off the ground. Under no circumstances, either during shipment or storage, shall the material be exposed to sunlight, or other form of light which contains ultraviolet rays, for more than five calendar days.

The area to be covered by the geotextile shall be graded to a smooth, uniform condition free from ruts, potholes, and protruding objects such as rocks or sticks. The geotextile shall be spread

immediately ahead of the covering operation. The geotextile shall not be left exposed to sunlight during installation for a total of more than five calendar days. The geotextile shall be laid smooth without excessive wrinkles. Under no circumstances shall the geotextile be dragged through mud or over sharp objects which could damage the geotextile. The cover material shall be placed on the geotextile in such a manner that a minimum of 6 inches of material, depending on the survivability of the geotextile, will be between the equipment tires or tracks and the geotextile at all times. Construction vehicles shall be limited in size and weight such that rutting in the initial lift above the geotextile is not greater than 3 inches deep, to prevent overstressing the geotextile. Turning of vehicles on the first lift above the geotextile will not be permitted. End-dumping the cover material directly on the geotextile will not be permitted. Compaction of the first lift above the geotextile shall be limited to routing of placement and spreading equipment only. No vibratory compaction will be allowed on the first lift.

Pegs, pins, or the manufacturer's recommended method shall be used as needed to hold the geotextile in place until the specified cover material is placed.

Should the geotextile be torn or punctured or the overlaps or sewn joints disturbed, as evidenced by visible geotextile damage, subgrade pumping, intrusion, or roadbed distortion, the backfill around the damaged or displaced area shall be removed and the damaged area repaired or replaced by the Contractor at no cost to the City. The repair shall consist of a patch of the same type of geotextile placed over the damaged area. The patch shall overlap the existing geotextile a minimum of 2 feet from the edge of any part of the damaged area.

The geotextile shall either be overlapped a minimum of 2 feet at all longitudinal and transverse joints, or the geotextile joints shall be sewn together.

Construction geotextile, for stabilization and landscape will be measured by the square yard for the ground surface area actually covered. The unit contract prices for Geotextile as included in the proposal shall be full pay to complete the work as specified.